



Western

# JOB HAZARD ANALYSIS - Task Specific

NEW

REVISED

**WORKPLACE TASK TO BE ANALYSED**

Installation of roof-mounted units

**DEPARTMENT**

Facilities Management

**WESTERN JOB CLASSIFICATION\***

Mechanical Trades (ACMF)

**REQUIRED EQUIPMENT AND/OR PERSONAL PROTECTIVE EQUIPMENT**

Protective clothing, fall arrest/life line (I.R.), knee pads, hearing protection (I.R.), gloves, grade 1 safety footwear, safety glasses/goggles, hard hats (I.R.)

**WESTERN HAZARD CATEGORY\***

WorkSite Hazards

**HAZARD TYPE\***

Working at Heights, working alone

**LOSS POTENTIAL RATING\***

High

\*refer to Stantec Specific Job Report

**DATE:**

March 17, 2021

**WRITTEN BY:**

Ken Hill

**REVIEWED BY:**

ACMF Shop

**MGMT APPROVAL:**

Ken Hill

SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDURE
Install buck/platform/isolators	Position, fall, sharp material, noise	Shut down notice if hazardous roof
Place/secure unit( by crane, I.R.), add required parts, seal/insulate/coat as necessary	Man-made mineral fibre, UV, cold stress, slip/fall,	PPE, proper lifting technique, WHMIS
		Fall arrest policy (I.R), assistance as required
		Work by licensed mechanic
*I.R. if required	*Required safe use of hand/power tools	