

**X** REVISED

**□NEW** 

## JOB HAZARD ANALYSIS - Task Specific

	L	<b>」</b> ··──	<u> </u>
WORKPLACE TASK TO BE ANALYSED	WESTERN HAZARD CATEGORY*		DATE:
Insulation of duct/fittings	Ergonomic/ WorkSite Hazards		March 17, 2021
DEPARTMENT	HAZARD TYPE*		WRITTEN BY:
Facilities Management	Awkward posture/ Sharps Objects		Ken Hill
WESTERN JOB CLASSIFICATION*	LOSS POTENTIAL RATING*		REVIEWED BY:
Mechanical Trades (ACMF)	Moderate		ACMF Shop
REQUIRED EQUIPMENT AND/OR PERSONAL PROTECTIVE EQUIPMENT	*refer to Stantec Speci	fic Job Report	MGMT APPROVAL:
Respiratory protection, gloves, grade 1 safety footwear, safety glasses/goggles			Ken Hill
SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDURE	
Check equipment for safe use	Position, sharp material	PPE, WHMIS	
Weld pins, cut insulation to size, apply adhesive, install insulation, apply clips	Burn, inhalation	Ventilation, rest periods	
Seal open end/clips with mastic	Repetitive strain injury	Proper cleanup/disposal	