

**x** REVISED

## JOB HAZARD ANALYSIS - Task Specific

NEW

WORKPLACE TASK TO BE ANALYSED	WESTERN HAZARD CATEGORY*	DATE:
Use of sewer machine	Chemical/ Ergonomic/ WorkSite Hazards	March 25, 2021
DEPARTMENT	HAZARD TYPE*	WRITTEN BY:
Facilities Management	Other Liquids/ Awkward posture/ pinch points	Ken Hill
WESTERN JOB CLASSIFICATION*	LOSS POTENTIAL RATING*	REVIEWED BY:
Mechanical Trades (plumbing)	Moderate	Plumbing/Fitting Shop
REQUIRED EQUIPMENT AND/OR PERSONAL PROTECTIVE EQUIPMENT	*refer to Stantec Specific Job Report	MGMT APPROVAL:
Coveralls, grade 1safety footwear, safety glasses/goggles, gloves, respiratory	protection (I.R.)	Dan Gyetvai

SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDURE
Inspect machine to ensure complete/ safe	Position, pinch point,	PPE, follow manufacturer's instructions
Place machine as required, lock wheels. test CFGI, feed cable forward, reverse when line cleared.	Chemical contact	Keep work area clear, verbal communication
Clean unit, cables, work area. (I.R.)	Human Blood and Bodily Fluids	Wash coveralls/clothing separately.
Where risk of splashin of fluids can occur wearing of goggles and respiratory protection is required		Assistance (I.R) work by experienced trade. Supervisors must complete a Hazards Communication Form for each staff member so that Workplace Health can administer the propoer medical surveillance programs for those staff.
I.R. = if required		
Type of machines		
*3belt/ drum/ drive with air actuated foot switch		