

JOB HAZARD ANALYSIS - Task Specific

		NEW	x REVISED
WORKPLACE TASK TO BE ANALYSED	WESTERN HAZARD C	ATEGORY*	DATE:
Internal Boiler Work (Waterside)	Energy/Ergonomic/W	orkSite Hazards	May 7, 2008
DEPARTMENT	HAZARD TYPE*		WRITTEN BY:
Facilities Management	Electricity/Overloading/Confined Space		Rod Crichton
WESTERN JOB CLASSIFICATION*	LOSS POTENTIAL RA	LOSS POTENTIAL RATING*	
Power Plant Staff	Moderate	Moderate	
REQUIRED EQUIPMENT AND/OR PERSONAL PROTECTIVE EQUIPMENT	*refer to Stantec Specific Job Report		MGMT APPROVAL:
Gloves, coveralls, knee pads, safety footwear			
SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDU	JRE
Lock-out energy sources	Energy hazard		g-out Procedure/Training to tional startup of equipment
	Б	D () L'(() D	

SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDURE
Lock-out energy sources	Energy hazard	Refer to Lock-out/ Tag-out Procedure/Training to eliminate the unintentional startup of equipment
Remove access doors	Back injury	Refer to Lifting Procedure/Training in removing access doors. Ask co-worker for assistance if needed. Keep work area clean and free of trip hazards.
Confined Space Entry Assessment - entry to take place without harness or life line because it has been determined that the harness and life line will be more determintal with than without due to entanglement. Air monitoring of space will maintained throughtout the entry and attendent will use the Confined Space Radio.	Claustrophobia, heat exhaustion	Refer to Confined Space Procedure/Training as ingress/egress is limited. Maintain good lines of communication. Heat can sometimes be an issue-take frequent breaks if needed.
Due to the decision of not using the harness or lifeline for entanglement reasons, a rescue team will be on-site any time an employee is in the steam or mud drum.	Injuries could occur during retrieval - cuts, bruises, etc	Use reliable, well trained rescue team
Enter steam/mud drum	Very small, tight space. Claustrophobia	Refer to Confined Space Procedure/Training as ingress/egress is limited. Maintain good lines of communication. Heat can sometimes be an issue -

Remove boiler internals	,	Refer to Lifting Procedure/Training. Maintain good lines of communication. Ask for assistance of a coworker if needed. Heat can be an issue - take frequent breaks if needed. Keep work area outside of confined space clean and free of trip hazards.
To complete the job - please reverse sequence of job steps and recommended actions		