



Notice of Service Interruption/Area Closure
Western University
Facilities Management
Client Services 519-661-3304 (fmhelp@uwo.ca)

Submit by E-mail
 Print Form

Date of Interruption/Closure **REVISED** Time(s):

Building(s) Affected: #1 #2
 #3 #4

Areas/Rooms Affected Alternate Route/Service:
 Building.

Service to be interrupted: #1 #2
 #3 #4

Description/Reason for Project:

Requester: Date of Request:

Supervising Tradesperson: Unit:

Trade Supervisor: Unit: Date:

Contractor: Phone #

Coordinator/Project Manager: Phone # Date:

Reviewed by Trade Supervisor(s)/Shop(s) Affected:

Name: <input type="text" value="WES Control"/>	Date: <input type="text" value="May 3, 2017"/>	Name: <input type="text"/>	Date: <input type="text"/>
--	--	----------------------------	----------------------------

Signature/Stamp: **REVIEWED**
 By Jesse Atkinson (jatkin48@uwo.ca) at 8:52 am, May 03, 2017

Signature/Stamp:

Principal Occupants:

Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>
Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>
Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>
Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>

Approval to Proceed: Date:

APPROVED
 By Dan Trudgeon (dtrudgeo@uwo.ca) at 3:14 pm, May 03, 2017

Notes:

HAZARDOUS EXHAUST SYSTEMS INVENTORY

BUILDING	CHEMISTRY
----------	-----------

SYSTEM #	ROOM #	FAN LOCATION	OUTLET LOCATION	USE	NOTES
001-500	COLLECTOR FAN – ROOF C				
002-500/501	COLLECTOR FAN – ROOF F				
003-500/501	COLLECTOR FAN – ROOF H				
004-500/501	COLLECTOR FAN – ROOF				
005	025	B	B	FUME CABINET	
006	030C	A	A	FUME CABINET	
007	032	A	A	FUME CABINET	PNL 1D #30
008	036	B	B	FUME CABINET	CAPPED OFF IN LAB BREAKER LOCKED OFF AT PNL 1G #18
009	036	B	B	FUME CABINET	
010	040 & 040B	C	C	RM 040 – 1 4FT FC	STROBIC FAN LOCATED ON ROOF C
				RM 040B- 1 – 8FT FC & 1 – FT FC	
011	092	C	C	FUME CABINET	
019	042	C	C	FUME CABINET	
020	074	C	C	MULTI FUME CAB	STUDENT LAB
021	074	C	C	MULTI FUME CAB	STUDENT LAB
022	074	C	C	MULTI FUME CAB	STUDENT LAB
023	074	C	C	MULTI FUME CAB	STUDENT LAB
024					
027	080	B	B	FUME CABINET	ELEPHANT TRUNK EX NOT IN USE!
029	084	A	A	FUME CABINET	ELEPHANT TRUNK EX
030	084	A	A	FUME CABINET	ELEPHANT TRUNK EX
031	084	A	A	FUME CABINET	ELEPHANT TRUNK EX
032	084	A	A	FUME CABINET	ELEPHANT TRUNK EX
033	094	C	C	FUME CABINET	ELEPHANT TRUNK EX
034	094	C	C	FUME CABINET	ELEPHANT TRUNK EX
035	094	C	C	FUME CABINET	ELEPHANT TRUNK EX
036	094	C	C	FUME CABINET	ELEPHANT TRUNK EX
037	094	C	C	FUME CABINET	ELEPHANT TRUNK EX
038	080	A	A	MULTI FUME CAB	TEACHING LAB RM. 080

SYSTEM #	ROOM #	FAN LOCATION	OUTLET LOCATION	USE	NOTES
039	080	A	A	MULTI FUME CAB	TEACHING LAB RM. 080
040	080	A	A	MULTI FUME CAB	TEACHING LAB RM. 080
041	080	A	A	MULTI FUME CAB	TEACHING LAB RM. 080
042	080	A	A	MULTI FUME CAB	TEACHING LAB RM. 080
121-006-501		D	D	GENERAL EXHAUST	NOT IN USE
121-007-501		N	N	WASHROOM EX.	
121-008-501	402	N	N	ELEV. EXHAUST	
121-009-501	401	N	N	MECH RM. EX.	
042-501	021	C	C	FUME CABINET	ORIGINALLY HOOD
043-501	023	C	C	HOOD	
044-501	036	B	B	HOOD	
045-501	036	B	B	HOOD	ELEC. SHOP TO INSTALL MOTOR STARTER IN MAY 2013
047-501	089	B	B	FUME CABINET	ORIGINALLY HOOD
055-501	079	A	A	EQUIPMENT EX.	4-SPECTROMETERS NO POWER NO POWER TO MOTOR FROM SWICH IN LAB AS OF MAY 2013
056-501	094A	C	C	FUME CABINET	
061-501	002A	002C	WALL	ROOM EXHAUST	
062-501		50	B	WR EXHAUST	
063-501	6B			ROOM EXHAUST	
069-501	50	50	WALL	MECH. ROOM EX.	
070-501	50A	NONE	WALL	TRANS. RM. EX.	LOUVRE- NO FAN
074-501	26	26		TRANS. RM. EX.	NAT. SCI. VAULT
075-501	30	30	WALL	TRANS. RM. EX.	
077-501	16		G		SEE NOTES
078-501	079	B	B	FUME CABINET	

NOTES:

-FANS HIGHLIGHTED IN YELLOW DENOTE NON-HAZARDOUS FANS.

-077-501 FIBREGLOSS DOME REMAINS ON ROOF "G"