Western

REVISED
8:12 am, Mar 26, 2014

Notice of Interruption/Area Closure
The University of Western Ontario
Facilities Management
Service Centre 519-661-3304 (ppdhelp@uwo.ca)

Submit by Email | Print Form

Date of Interruption/Closure	March 31, 2014	Time(s):	7am - 1:30pm

Building(s) Affected: #1	Health Sciences Addition	#2	
#3		#4	
Areas/Rooms Affected	All fume hoods.		
Alternate Route/Service:			

Service to be interrupted: #1	Hazardous Exhaust	#2	
#3		#4	
Description/ Reason for Project:	All fumehoods will be shut down for roof top work regarding crane operation to mechanical penthouse		

Requester:	Mark Widmeyer	Date of Request:	Feb 26, 2014
Supervising Tradesperson:	Mark Widmeyer	Unit:	Electrical
Trade Supervisor:	Doug Johnson	Unit:	Electrical — Date:Feb 26, 2014
Contractor:		Phone #	
Coordinator/Project Manager:		Phone #	Date:

Reviewed by Trade Supervisor(s)/Shop(s) Affected:

Name:	Electrical Shop	Name:	Electrical Mechanical
Date:	Feb 26, 2014	Date:	Feb 26, 2014
Signature/ Stamp:	Mark Widmeyer	Signature/ Stamp:	APPROVED By Steve Pepper (spepper@uwo.ca) at 7:24 am, Feb 27, 2014

Reviewed by:

Name:	Date:
Signature/ Stamp:	

Principal Occupants:

Name:	Ext.	Date:
Name:	Ext.	Date:
Name:	Ext.	Date:
Name:	Ext.	Date:

Approval to Proceed:	Date:	Approval to Proceed:	Date:
		APPROVED By Andrew (amerucci@uwo.ca) at 8:26 am, Mar 03, 2014	

Notes:

265522 motor shop
265521 grounds

HAZARDOUS EXHAUST SYSTEMS

FAN SHUTDOWN LISTINGS

HEALTH SCIENCE ADDITION - ROOFS C,E

DATE OF SHUT DOWN -	
OFF BY	
ON BY	

REASON FOR SHUTDOWN
ANNUAL HAZARDOUS ROOF SHUTDOWNS

ROOM NUMBER	SYSTEM NUMBER	USE	CONTACTS
202	OO2	FUME CABINET	
216	OO3	FUME CABINET	
301 H&I	O10	BIO-HAZARD ROOM - CENTRIFUGE EXHAUST	
301 G & F	OO6	FUME CABINET	
406	O12	FUME CABINET	
408	OO7	FUME CABINET	
415	O13	FUME CABINET	
418	OO8, OO9	FUME CABINETS	

HAZARDOUS EXHAUST SYSTEMS

FAN SHUTDOWN LISTINGS

DENTAL SCIENCE - ROOF C

DATE OF SHUT DOWN -	
OFF BY	
ON BY	

REASON FOR SHUTDOWN

ROOM NUMBER	SYSTEM NUMBER	USE	OFF	ON
2003	O40	FUME CABINET	TURN OFF AT PANEL 5P - cir.#1 NEAR RM. 4006 CORRIDOR AND INSTALL WARNING SIGN ON FUME CABINET	
2005	35		ELEPHANT TRUNKS PANEL 5P CIRCUIT # 3	
2005	36		ELEPHANT TRUNKS PANEL 5P CIRCUIT # 6	
2010B	37		DOUBLE SIDED FUME CABINET PANEL 5P CIRCUIT #14	
2011	38		FUME CABINET PANEL 5P CIRCUIT # 21	
3003	O44	DARK ROOM EXHAUST	FUME CABINET	
3003D	O42	FUME CABINET	TURN OFF AT PANEL 5P-cir.7 ON 4TH FLOOR COORIDOR NEAR 4006 AND INSTALL WARNING SIGN ON FUME CABINET	
3004	O45, O46, O47	FUME CABINET		
3005B	O49	FUME CABINET		
3006B	O52	FUME CABINET		
4010	O78	FUME CABINET		
4011	O62	FUME CABINET		
4012	O63	EQUIPMENT EXHAUST		
4014	O64	HOOD		
4015	O65	FUME CABINET		

2 SIGNS REQUIRED