



Notice of Service Interruption/Area Closure
Western University
Facilities Management
Client Services 519-661-3304 (fmhelp@uwo.ca)

Submit by E-mail
 Print Form

Date of Interruption/Closure: Time(s):

Building(s) Affected: #1 #2
 #3 #4

Areas/Rooms Affected Alternate Route/Service:
 Building.

Service to be interrupted: #1 #2
 #3 #4

Description/Reason for Project:

Requester: Date of Request:

Supervising Tradesperson: Unit:

Trade Supervisor: Unit: Date:

Contractor: Phone #

Coordinator/Project Manager: Phone # Date:

Reviewed by Trade Supervisor(s)/Shop(s) Affected:

Name: <input type="text" value="WES Control"/>	Date: <input type="text" value="May 3, 2017"/>	Name: <input type="text"/>	Date: <input type="text"/>
Signature/Stamp: REVIEWED <i>By Jesse Atkinson (jatkin48@uwo.ca) at 8:53 am, May 03, 2017</i>		Signature/Stamp: <input type="text"/>	
Name: <input type="text"/>	Date: <input type="text"/>	Principal Occupants:	
Signature/Stamp: <input type="text"/>	Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>
Name: <input type="text"/>	Date: <input type="text"/>	Name: <input type="text"/>	Ext. <input type="text"/>
Signature/Stamp: <input type="text"/>	Name: <input type="text"/>	Ext. <input type="text"/>	Date: <input type="text"/>
Name: <input type="text"/>	Date: <input type="text"/>	Name: <input type="text"/>	Ext. <input type="text"/>
Signature/Stamp: <input type="text"/>	Approval to Proceed: <input type="text"/>		
Name: <input type="text"/>	Date: <input type="text"/>		
Signature/Stamp: <input type="text"/>	APPROVED <i>By Dan Trudgeon (dtrudgeo@uwo.ca) at 3:23 pm, May 08, 2017</i>		

Notes:

HAZARDOUS EXHAUST SYSTEMS INVENTORY

LAST UPDATED : 2013 / 04 / 30

BUILDING	SPENCER ENGINEERING BUILDING
----------	------------------------------------

SYSTEM #	ROOM #	FAN LOCATION	OUTLET LOCATION	USE	NOTES
330-001-500	4012	4012	WALL	MACH. RM. EX.	
002	1007	4002	ROOF B	SILICA SAND EX.	
003		R	R	WASHROOM EX.	
004		4013	WALL J	WASHROOM EX.	LOUVER ABOVE ROOF J
005	3105C	S	S	DARK ROOM EX.	
006	1060-1076	S	S	WASHROOM / ROOM EX.	
007	2092	S	S	PAINT BOOTH	
008	2096	S	S	ROOM EX.	CARETAKER ROOM
009	1076	R	R	ENGINE EX.	FLOOR CHASE
010	PIPE TUNNEL BASEMENT	WELL BY FRONT ENTRANCE	WELL BY FRONT ENTRANCE	PIPE TUNNEL EX.	OLD ORIGINAL EX. FAN REMAINS IN TUNNEL
011	1053	4003	A	ROOM EXHAUST	
013	3067	4002	A	ROOM EXHAUST	MAY HAVE BEEN REMOVED
014	01	01	WALL	COMPRESSOR ROOM	ROOM EXHAUST
015	21F-1	ROOF R	ROOF R	CARETAKER BREAK ROOM EX.	NOT IN USE
016	4003	A	A	MECH. RM. EX.	
017	4002	A	A	MECH. RM. EX.	
018	1082	R	R	FUME CABINET	
019	1079	R	R	FUME CABINET	OPEN INTO 1078
020	1081	4011	WALL J	FUME CABINET	LOUVER ABOVE ROOF J
021	1080	4011	H	ROOM/AMONIA SCRUBBER EX. RM. 1081	
022	6	4003	D	FUME CABINET	
023	3052	4003	A	FUME CABINET	
024	3074	A	A	FUME CABINET	
025	3072	4003	A		
026	3068	4003	A	FUME CABINET	RENOS *FOLLOW UP BEFORE ROOF SEASON 2014*
027	3063	4003	A	HOOD	
028	3063	4003	A	HOOD	

029	3063	4003	A	HOOD	
030	3054	4003	A	HOOD	
032	22A	4003	A	HOOD	
033	1053	4003	A	FUME CABINET	
036	1082 & 1083	LOAD DOCK	R	ELEPHANT TRUNK	
SYSTEM #	ROOM #	FAN LOCATION	OUTLET LOCATION	USE	NOTES
037	1083	LOAD DOCK	R	FUME CABINET	
039	42A	42A	LD WALL	MECH. RM. EX.	
044	15	D	D	FUME CABINET	
045	19A	D	D	FUME CABINET	
046	19A	D	D	FUME CABINET	
047	2025	D	D	FUME CABINET	
048	2025	D	D	FUME CABINET	
049	2032	D	D	FUME CABINET	
050	2032	D	D	FUME CABINET	
051	2035	D	D	FUME CABINET	
052	2036	D	D	FUME CABINET	
053	2026	D	D	FUME CABINET	
054	3015	D	D LABELED A	FUME CABINET	
055	3015	D	D LABELED A	FUME CABINET	
056	3015	4002	D LABELED A	EQUIP. EX.	PORE SIZER
057	3100	3100	S	SOLDERING EX.	ELICENT FAN – INLINE
058	3098A	S	S	DARK RM. EX.	
059	3064	4002	A	EQUIP. EX.	DIESEL FUEL EXHAUST CHECK ROOF FOR FAN MAY BE GONE!!!!
ALL HYDROGEN EXHAUST EQUIPMENT REMAIN ON SITE – NO LONGER IN USE. COULD BE RECOMISSIONED AT ANY TIME.					
060	24,3047,305 1,3055A	4003	D	EQUIP EXHAUST	HYDROGEN EX. MONITORED BY W.E.S
061	1062	1062	WALL	ELECT. VAULT EX.	
062	17,2013(2), 2017,2026,3 042	ROOF D	ROOF D	FUME CABINET EXHAUST	STROBIC (COLLECTOR) FAN SERVING 6 FUME CABINETS & ELEPHANT TRUNKS
063	1204	1204	SOUTH WALL	MECH. RM. EX.	
064		ROOF NEW ADDITION	ROOF NEW ADDITION	W.R. EXHAUST NEW ADDITION	
103-505		4002	D	W.R. EXHAUST	
103-506		4002	D	BLDG. EXHAUST	
104-506	1035A	4003	A	ROOM EXHAUST	
104-507	3074	A	A	ROOM EX.	
NO SYSTEM #	3102		S		FC/FAN REMOVED
NO SYSTEM #	1A	1A	WALL	BATTERY STORAGE	
NO SYSTEM #	1076B,C,D	1076B	WINDOW	ROOM EX.	
NO SYSTEM #	1071	1071	WINDOW	HOOD	

NO SYSTEM #		ROOF	ROOF	ROOM EX.	NOT IN USE (NOTE 1)

NOTES:

1 – THIS FAN IS ON THE ROOF ABOVE LOADING DOCK. (NO DESIGNATION)