


POLICY: EMERGENCY SHOWER AND EYEWASH STATIONS		NUMBER: S-25
		Page 1 of 1
PREPARED BY: Facilities Management (FM)	AUTHORIZED BY  Lynn Logan	CLASSIFICATION: Safety Procedure
		EFFECTIVE: July 1, 2015
		SUPERSEDES: February 10, 2010

All new emergency showers and eyewash stations installed must:

- be manufactured according to ANSI Z358.1-2004 and installed in accordance with the manufacturer's recommendation.
- be connected to permanent potable waterlines that are protected by a backflow preventor (new or existing), and drains.
- be located within 75 feet from the location of the furthest potential hazard and with no more than one door opening in the direction of travel.
- have any shut-off valve on the water line serving the fixtures tagged to prevent the valves from being closed except for maintenance.
- have primary valve for the fixture remain open until intentionally closed.
- be installed so that the shower head is no less than 82 inches or more than 96 inches from the floor and be capable of delivering 20 gallons/minute for a minimum of 15 minutes. The spray pattern shall be a minimum of 20 inches and such pattern shall be at least 16 inches away from any obstruction.
- be installed so that the eyewash is no less than 33 inches or more than 45 inches from the floor and be capable of delivering 0.4 gallons/min for a period of 15 minutes.
- emergency showers to be tested monthly by Caretakers and annually by the Plumbing Shop.
- eyewash stations in corridors to be inspected/tested weekly by Caretakers.
- eyewash stations in laboratories to be inspected/tested weekly by Laboratory personnel.

Any deviation from this standard must be approved by the Executive Director of Facilities Development and Engineering.