

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3641	Mike	PAB214	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Small, Canadian Tire branded, fridge in laboratory is not labelled.

Action

Please label as to class/type of contents. An inventory, affixed to the outside in advised.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3642	Mike	BGS1000E	Biological & Geological Sciences	Earth Sciences

Description of Violation

Unused 'office cubicle barriers' stored in hallway outside BGS1000E. Storage not permitted in hallways.

Action

Please remove from hall and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3643	Mike	BGS1007	Biological & Geological Sciences	Earth Sciences

Description of Violation

Glass jug containing clear liquid is unlabelled.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3644	Mike	BGS1038	Biological & Geological Sciences	Earth Sciences

Description of Violation

Departmental First Aid station requires..
 1. First Aid poster to be displayed
 2. Monthly checking by First Aid Rep and white tag completed.

Action

Please correct. First Aid supplies, etc can be obtained from OHS. Contact Sintia at Externsion 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3645	Mike	BGS1060	Biological & Geological Sciences	Earth Sciences

Description of Violation

Labelled flammable storage cabinet used to store bases.

Action

Please relabel cabinet as to correct contents. Label clearly "BASES".

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3646	Mike	BGS1055	Biological & Geological Sciences	Earth Sciences

Description of Violation

Unused fluorescent tubes stored on top of electrical raceway. Could easily roll off on to floor and shatter.

Action

Please remove and store in a safe manner elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3647	Mike	BGS1053	Biological & Geological Sciences	Earth Sciences

Description of Violation

Large rock being used as doorstop and left in middle of egress route. Trip hazard.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3648	Mike	B6D Hallway/Sta	Biological & Geological Sciences	Earth Sciences

Description of Violation

Unused items abandoned and stored in corridor and at bottom of stairwell in the area of BGS36D. Items are not to be stored in the hallway.

Action

Please remove and store safely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3649	Mike	BGS0127	Biological & Geological Sciences	Earth Sciences

Description of Violation

Railing/barrier must be installed around pit immediately to prevent accidental fall and injury.

Action

Please install barrier immediately. Rope/chain off area. Post signs. Contact Facilities Management to ensure railing meets code.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3650	Mike	BGS0135	Biological & Geological Sciences	Earth Sciences

Description of Violation

Evidence of food being consumed where hazardous materials are present.

Action

Please do not eat or drink in the lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3651	Mike	BGS0155	Biological & Geological Sciences	Earth Sciences

Description of Violation

Access to eyewash blocked by old CRT monitors left on floor. Eyewash has not been checked weekly as required.

Action

Please clear pathway. Store monitors elsewhere. Affix blue tag and test eyewash weekly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3652	Mike	BGS0132	Biological & Geological Sciences	Earth Sciences

Description of Violation

Tarp left on floor at entrance to storage/junk room presents a trip hazard.

Action

Please remove and store safely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3653	Mike	BGS0074A	Biological & Geological Sciences	Earth Sciences

Description of Violation

Chemicals improperly labelled. Some have not label, some labelled unclearly and some labelled in code.

Action

All chemicals must be clearly labelled with full, and understandable, chemical name. Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3654	Mike	ays outside BGS	Biological & Geological Sciences	Earth Sciences

Description of Violation

Discarded items left in hallway. Include pallet, cupboards, etc. Hallways are not dumping grounds and/or storage areas.

Action

Please clear items from hallways immediately.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3655	Mike	BGS0156	Biological & Geological Sciences	Earth Sciences

Description of Violation

Chemical fridge requires labelling on front to indicate NO FLAMMABLES.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3656	Mike	WSC54	Western Science Centre	Earth Sciences

Description of Violation

Glass panels leaning against wall and not secured. Could fall over.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3657	Mike	WSC58	Western Science Centre	Earth Sciences

Description of Violation

Cable guard in becoming loose and presents trip hazard.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3658	Mike	WSC58	Western Science Centre	Earth Sciences

Description of Violation

Loose MS panels in walkway could fall over.

Action

Please relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3659	Mike	WSC54	Western Science Centre	Earth Sciences

Description of Violation

Base cabinet label small and hard to read.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3660	Mike	WSC262	Western Science Centre	Statistical & Actuarial Sciences

Description of Violation

First Aid Certification card for rep is out of date.

Action

Please update

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3661	Mike	Various	Natural Sciences Centre	Psychology

Description of Violation

Numerous 'free standing' shelving units in various rooms need to be anchored to the wall to prevent falling over. Rooms include (but are not limited to) NSC 212,213,214.

Action

John Cesarini will check all rooms in Centre and anchor shelving units as required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3662	Mike	Various	Natural Sciences Centre	Psychology

Description of Violation

Numerous extension cords in various rooms need to be removed and replaced with power bars.. Rooms include (but are not limited to) NSC 213,214.

Action

Please remove extension cords and replace with power bars.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3663	Mike	NSC213	Natural Sciences Centre	Psychology

Description of Violation

Table stored on side with legs protruding into route of egress. At eye level and could be bumped in to.

Action

Please remove table or store in a safe manner.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3664	Mike	NSC216 and 217	Natural Sciences Centre	Psychology

Description of Violation

In two rooms elevated floor drops off by one step near exit doors. Not easily seen and presents a trip/fall hazard.

Action

John Cesarini will make step more visible by marking off with striped marking tape.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3665	Mike	NSC245	Natural Sciences Centre	Psychology

Description of Violation

First Aid Kit does not have certificate of First Aid rep displayed or monthly checklist.

Action

Please post a copy of certificate. Any supplies or checklist can be obtained from OHS by calling Sintia at extension 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3666	Mike	BGS3004.	Biological & Geological Greenhouse	Physical Plant - Maintenance

Description of Violation

Ceiling tile is not in place and is sitting on edge. Appears that it could fall on occupants below. In corner area.

Action

Please investigate and replace as necessary.

Comments

WO 198314

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3667	Mike	BGS3053	Biological & Geological Greenhouse	Biology

Description of Violation

Many bottles are labelled only with a short form rather than a full chemical name.

Action

Please label fully. Legends posted for common short forms are acceptable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3668	Mike	BGS3053	Biological & Geological Greenhouse	Biology

Description of Violation

Student working in the lab, performing operations, not wearing safety glasses.

Action

Supervisor, in conjunction with workers, is responsible for ensuring that personal protective equipment is worn. Char and supervisor to develop a program to ensure workers comply..

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3669	Mike	BGS2055	Biological & Geological Greenhouse	Biology

Description of Violation

Improper chemical storage. Acetic acid stored in acid cabinet rather than in flammable storage cabinet.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3670	Mike	BGS0101	Biological & Geological Greenhouse	Biology

Description of Violation

Used fluorescent tubes stored upright in garbage pail, unsecured, and could topple over and break. Sign right beside them states that they should be stored securely on their side!!

Action

Please correct. Users of the room must be informed of the importance of following procedures and signage for the room

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3671	Mike	BGS0064	Biological & Geological Greenhouse	Biology

Description of Violation

In aquarium room there are a number of power bars daisy chained and extension cords in use. Extension cords are not permitted and only one power bar is permitted between the source receptacle and the device being powered.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3672	Mike	Day outside BGS	Biological & Geological Greenhouse	Biology

Description of Violation

Old, unused fluorescent fixtures stored in hallway. Storage in hallways is not permitted, even for the short term. Presents trip hazard.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3673	Mike	G12 (off G11)	Biological & Geological Greenhouse	Physical Plant - Maintenance

Description of Violation

Tiltes lifting off floor in "Seed Room" in greenhouse. Seed Room is G12 which is off G11. Presents trip/slip hazard.

Action

Please repair/replace/remove.

Comments

WO 198318

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3674	Mike	WSC329	Western Science Centre	Biology

Description of Violation

Not all chemicals clearly labelled in Acid Cabinet. One bottle contents labelled as "3 Weeks Old"

Action

Please review. Purge as necessary. Ensure all contents are clearly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3675	Mike	WSC329 hallway	Western Science Centre	Biology

Description of Violation

A number of fridges 'owned' by various researchers are in the alcove area of the hallway outside WSC329. They fridges need to be labelled as to the lab/owner.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3676	Mike	WSC313	Western Science Centre	Biology

Description of Violation

A couple of chemical storage issues in the acid cabinet. There are unused acids to be disposed of and acetic acid that needs to be removed to flammable storage cabinet.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3677	Mike	WSC313	Western Science Centre	Biology

Description of Violation

Extra acid cabinet used to store bases. Still labelled as acid cabinet.

Action

Please clearly relabel as BASES.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3678	Mike	WSC361	Western Science Centre	Biology

Description of Violation

Many bottles are labelled only with a short form rather than a full chemical name.

Action

Please label fully. Legends posted for common short forms are acceptable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3679	Mike	WSC361	Western Science Centre	Biology

Description of Violation

Many bottles are labelled only with a short form rather than a full chemical name. Some bottles are unlabelled.

Action

Please label fully. Legends posted for common short forms are acceptable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3680	Mike	WSC355	Western Science Centre	Biology

Description of Violation

Many bottles are labelled only with a short form rather than a full chemical name. Some bottles are unlabelled.

Action

Please label fully. Legends posted for common short forms are acceptable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3681	Mike	WSC355	Western Science Centre	Biology

Description of Violation

Acetic Acid incorrectly stored in Acid cabinet.

Action

Please remove and store correctly in Flammable Storage cabinet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3682	Mike	WSC355	Western Science Centre	Biology

Description of Violation

Floor and aiseways cluttered. Possible trip hazard.

Action

Please store/shelve items off floor.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3683	Mike	WSC357 Area	Western Science Centre	Biology

Description of Violation

No eyewash station available. This order has be written up previously in Lab Safety inspections.

Action

Please work with Facilities Engineering and have eyewash installed soon.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3684	Mike	Loading Dock A	Biological & Geological Sciences	Physical Plant - Maintenance

Description of Violation

Large orange stepladder laying in hallway on side adjacent to exit. Stored incorrectly. Could fall over and present a trip hazard. In loading dock area of BGS by south exit toward Duck House.

Action

Please remve and store correctly.

Comments

WO 198327

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3685	Tony	Carpentry Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Cabinet above eyewash station blocks access.

Action

Please remove/relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3686	Tony	Carpentry Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Metal clamps in the back corner of shop need securing.

Action

Please secure.

Comments

198332

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3687	Tony	Carpentry Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Hearing Protection and Eye Protection Required signs anre not posted on entrance door.

Action

Please post.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3688	Tony	Paint Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Fridge for food should not be located in the shop where hazardous materials are present.

Action

Please remove and relocate. Office area is suggested.

Comments

198347

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3689	Tony	Motor Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Materials are stored in front of electrical panel. A 3 foot clear area is required.

Action

Please remove materials and keep area clear.

Comments

198350

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3690	Tony	Motor Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Loose electrical wire under desks may present a trip hazard.

Action

Please correct.

Comments

198352

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3691	Tony	Motor Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Items improperly stored on shop floor crowds area and may present a trip hazard.

Action

Please correct.

Comments

198352

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3692	Tony	Plumbing Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Items improperly stored on shop floor crowds area and may present a trip hazard.

Action

Please correct.

Comments

198355

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3693	Tony	Plumbing Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Items placed under drench/safety shower prevent access in case of emergency. A 2' radius from shower head must be maintained at all times

Action

Please correct and ensure area is kept clear at all time.s

Comments

198357

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3694	Tony	Plumbing Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Shelf above eyewash station impedes access. Area must be clear.

Action

Please remove shelf.

Comments

198358

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3695	Tony	Plumbing Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Pipes stored vertically, in corner, have not been secured. Could topple over.

Action

Please secure.

Comments

198359

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3696	Tony	Plumbing Shop	Support Services Building	Physical Plant - Maintenance

Description of Violation

Evidence of food and drink being consumed in shop. Food and drink are not allowed in shop area.

Action

Please restrict consumption of food to the office area and cafeteria.

Comments

198364

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3697	Tony	FM Stores	Support Services Building	Physical Plant - Maintenance

Description of Violation

Self Contained Breathing Apparatus (SCBA) has not yet been mounted as was decided at the FM JHSC meeting earlier.

Action

Please mount.

Comments

198366

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 27, 2012	Mar 6, 2012	2012-3698	Tony	FM Stores	Support Services Building	Physical Plant - Maintenance

Description of Violation

Laser tripod and ladders have not been secured and could fall over.

Action

Please secure to a fixed structure.

Comments

198368

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3699	Mike	loading Dock 050	Biotron	Biotron

Description of Violation

In the room between the loading dock and cryogenic room boxes are piled precariously and other materials stored in a poor fashion..

Action

Please organize and erect proper shelving to accommodate storage. Alternatively purge materials or have owner store in their area.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3700	Mike	Various	Biotron	Biotron

Description of Violation

Many emergency (yellow) door signs have outdated and incorrect information.

Action

Please update.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3701	Mike	loading Dock Area	Biotron	Biotron

Description of Violation

Long materials propped up in corner, untethered. Could fall over.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3702	Mike	CB206A	Collip Building	Biology

Description of Violation

Extension cords in use. Extension cords passing through ceiling area. Extension cords not permitted.

Action

Please remove. Have receptacles installed where needed or use power bars.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3703	Mike	NCB348	North Campus Building	Biology

Description of Violation

ABS piping stored on side on top of shelving unit. Could topple off.

Action

Please secure or remove and store safely.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3704	Mike	NCB Cold Room	North Campus Building	Biology

Description of Violation

Waste bottles stored on floor in cold room. Could be kicked and break/spill.

Action

Please store appropriately.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3705	Mike	NCB407	North Campus Building	Biology

Description of Violation

Bottles stacked on top of bottles in flammable storage cabinet. Should be stored on secure shelf.

Action

Please reorganize, purge and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3706	Mike	NCB468	North Campus Building	Biology

Description of Violation

Extension cord. Extension cords not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3707	Mike	NCB467	North Campus Building	Biology

Description of Violation

Desk stored on side in front of door. Impedes egress.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 3, 2012	Mar 13, 2012	2012-3708	Mike	NCB464A	North Campus Building	Biology

Description of Violation

Blue extension cord in use. Also presents trip hazard.

Action

Please remove. Have receptacle installed.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3709	Mike	Most labs.	Medical Sciences Building	Biochemistry

Description of Violation

Many short forms used in labelling with no 'legend' posted as to the meaning of the short forms. THIS IS A DEPARTMENTAL WIDE PROBLEM.

Action

Please post a comprehensive short form list in each lab that covers all the short forms used. Otherwise always ensure that the full chemicals name is shown in full on every bottle. Consider strongly developing a departmental wide list that covers all researchers.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3710	Mike	MSB359	Medical Sciences Building	Biochemistry

Description of Violation

Acetic acid stored incorrectly in acid cabinet. Should be stored with flammables.

Action

Please correct. Review all chemical storage in lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3711	Mike	labs in all buildin	Medical Sciences Building	Biochemistry

Description of Violation

Many blue eyewash tags show that eyewashes have not been checked weekly by members of the lab, as required.

Action

Please ensure researchers check eyewashes weekly. Monitor compliance

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3712	Mike	MSB367	Medical Sciences Building	Biochemistry

Description of Violation

Chemical bottles stored on floor os cold room. Improper location. Could be kicked.

Action

Please remove and store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3713	Mike	MSB369	Medical Sciences Building	Biochemistry
Description of Violation				Action		
Door was propped open. Must be closed at all times. No one in lab.				Ensure door always closed. Remove door stop to prevent use.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3714	Mike	MSB372	Medical Sciences Building	Biochemistry
Description of Violation				Action		
Extension cord in use. Extension cords not permitted.				Pleee remove. Consider using a power bar.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3715	Mike	MSB314	Medical Sciences Building	Biochemistry
Description of Violation				Action		
Items stores on top of centre shelves too close to ceiling. A mininum of 18" clearance must be left to allow efficient spray of sprinklers.				Pleasee remove items.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3716	Mike	MSB3335	Medical Sciences Building	Biochemistry
Description of Violation				Action		
Items stores on top of centre shelves too close to ceiling. A mininum of 18" clearance must be left to allow efficient spray of sprinklers.				Pleasee remove items.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3717	Mike	MSB329	Medical Sciences Building	Biochemistry

Description of Violation

Items stored on top of centre shelves too close to ceiling. A minimum of 18" clearance must be left to allow efficient spray of sprinklers.

Action

Please remove items.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3718	Mike	MSB323	Medical Sciences Building	Biochemistry

Description of Violation

Items stores on top of centre shelves too close to ceiling. A minimum of 18" clearance must be left to allow efficient spray of sprinklers.

Action

Please remove items.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3719	Mike	MSB335	Medical Sciences Building	Biochemistry

Description of Violation

Acetic acid stored incorrectly in Acid Cabinet. Should be in flammable storage cabinet.

Action

Please correct and review all chemical storage in the lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3720	Mike	MSB333	Medical Sciences Building	Biochemistry

Description of Violation

Electrical cord passing through doorway between rooms. Not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3721	Mike	MSB333	Medical Sciences Building	Biochemistry

Description of Violation

Dewars on floor in pathway. Present trip hazard.

Action

Please remove and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3722	Mike	MSB365	Medical Sciences Building	Biochemistry

Description of Violation

All fridges, freezers and instruments not clearly labeled as to owner and contact.

Action

Please label fridges, freezer and instruments clearly as to ownership. Makes contact easy in case of emergency.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3723	Mike	MBL C300	Molecular Biology Laboratory	Biochemistry

Description of Violation

Skids stored on side. Could fall over.

Action

Please secure/tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3724	Mike	MBL C301	Molecular Biology Laboratory	Biochemistry

Description of Violation

Flammable storage in old, unapproved flammable storage cabinet.

Action

Please remove chemicals and store in approved cabinet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3725	Mike	MBL C301	Molecular Biology Laboratory	Biochemistry

Description of Violation

Not all chemicals are labelled and are stored improperly around lab.

Action

Please correct. Purge to hazardous waste those that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 5, 2012	Mar 15, 2012	2012-3726	Mike	cond Floor Corridor	Molecular Biology Laboratory	Physical Plant - Caretaking

Description of Violation

Fire extinguisher in 2nd floor hallway of MBL has not been checked lately and red tag completed.

Action

Please check.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 6, 2012	Mar 16, 2012	2012-3727	Anne Marie	various	Materials Science Addition	Physical Plant - Caretaking

Description of Violation

Safety showers have not been flushed monthly

Action

Test safety showers monthly

Comments

Complete 2/13/12

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 6, 2012	Mar 16, 2012	2012-3728	Anne Marie	216	Chemistry Building	Physical Plant - Maintenance

Description of Violation

Two of the three lights in this room have burnt out

Action

Replace light bulbs

Comments

Work order 199114

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 6, 2012	Mar 16, 2012	2012-3729	Anne Marie	201	Chemistry Building	Physical Plant - Maintenance

Description of Violation

The fumehood monitor is in alarm (reading around 40). The Face velocity testing passed this year

Action

Repair/calibrate monitor

Comments

Work order 199113
Complete 22/3/12

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3730	Mike	MBL C204	Molecular Biology Laboratory	Biochemistry

Description of Violation

Signage (yellow) door is incomplete/incorrect.

Action

Please update. Kyle has blank yellow lab doors signs available.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3731	Mike	MBL C209	Molecular Biology Laboratory	Biochemistry

Description of Violation

Buildup of combustibles (broken down boxes) in room.

Action

Please remove/organize.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3732	Mike	MBL C103	Molecular Biology Laboratory	Biochemistry

Description of Violation

Extension cord used to power fridge. Extension cords not permitted.

Action

Please remove and plug fridge line cord directly into duplex outlet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3733	Mike	MBL C11	Molecular Biology Laboratory	Biochemistry

Description of Violation

All chemicals must be clearly labelled with full chemical names. Test tubes not fully labelled.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3734	Mike	DSB5014	Dental Sciences Building	Biochemistry

Description of Violation

Completed yellow lab door sign not displayed on door.

Action

Please fill out and display door sign.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3735	Mike	DSB5011	Dental Sciences Building	Biochemistry

Description of Violation

Old CRT monitors etc (from retired Sun computer) stored on top of desk shelf units. Not secure. Could fall off.

Action

Please remove and store securely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3736	Mike	SDRI112	Siebens Drake Research Institute	Biochemistry

Description of Violation

Some chemicals are unlabelled. All chemicals must be clearly labelled with full chemical name.

Action

Please ensure all chemicals are labelled and stored properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3737	Mike	SDRI109	Siebens Drake Research Institute	Biochemistry

Description of Violation

Not all chemicals in fridge are fully labelled.

Action

Please review all contents of the fridge. Purge all chemicals that are no longer needed, review condition and ensure all are labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3738	Mike	SDRI108A	Siebens Drake Research Institute	Biochemistry

Description of Violation

Untethered cylinder. Gas cylinders must be tethered upright.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3739	Mike	SDRI G20	Siebens Drake Research Institute	Biochemistry

Description of Violation

Erlynmeyer labelled as 'Courtney'. Labelling must show full chemical name.

Action

Please review all chemicals in lab to ensure contents have full chemical name on label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3740	Mike	SDRI G31B	Siebens Drake Research Institute	Biochemistry

Description of Violation

Extension cord (orange) in use. Also daisy chained. Extension cords not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3741	Mike	SDRI G31F	Siebens Drake Research Institute	Biochemistry

Description of Violation

Bottles of chemical sitting on top of flammable storage cabinet.

Action

Please store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3742	Mike	SDRI G31F	Siebens Drake Research Institute	Biochemistry

Description of Violation

Items stored above cupboards in centre of room too close too ceiling. 18" must be left open so that sprinklers can be effective.

Action

Please remove items so that 18" clearance is maintained.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3743	Mike	SDRI G31F	Siebens Drake Research Institute	Biochemistry

Description of Violation

Some chemicals in fumehoods are not labelled.

Action

Please label with full chemical names.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 9, 2012	Mar 19, 2012	2012-3744	Mike	SDRI G31F	Siebens Drake Research Institute	Biochemistry

Description of Violation

Many fridges have an inventory that is 8 years old.

Action

Please update inventory and review all fridge contents. Purge as necessary. Ensure all contents labelled with full chemical name.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3745	Mike	DSB 1016	Dental Sciences Building	Dentistry, School of

Description of Violation

Boxes piled around perimeter of boardroom pose a trip hazard and make egress difficult.

Action

Please correct. Store items properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3746	Mike	outside DSB101	Dental Sciences Building	Physical Plant - Maintenance

Description of Violation

Access panels in hallway outside DSB1017 and DSB1007 are in poor repair and are held partially closed with duct tape. Protrude into hallway.

Action

Please repair properly (rather than using duct tape).

Comments

WO 199645

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3747	Mike	DSB0060	Dental Sciences Building	Dentistry, School of

Description of Violation

First aid station requires
 1. Current certificate of First Aid rep posted.
 2. Monthly checking completed and white record card initialled.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3748	Mike	DSB0009	Dental Sciences Building	Physical Plant - Maintenance

Description of Violation

Tape is peeling off orange plastic and plastic coming off. Heat rise/smoke detector is not secure and is dangling.

Action

Please correct.

Comments

WO 199649

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3749	Mike	DSB B2	Dental Sciences Building	Dentistry, School of

Description of Violation

Surplus T-Bar not stored properly. Falling over. Presents trip hazard.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3750	Mike	ray outside DSB	Dental Sciences Building	Microbiology & Immunology

Description of Violation

Combustibles stored in hall. Old, abandoned, hard cover books.

Action

Please remove. Store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3751	Mike	DSB3013	Dental Sciences Building	Microbiology & Immunology

Description of Violation

Poor chemical storage. Flammables stored outside flammable storage cabinet.

Action

Please review chemical storage and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3752	Mike	hallway outside 30	Dental Sciences Building	Microbiology & Immunology

Description of Violation

Flammable storage cabinet in hallway. Still in packaging. Storage in hallway not permitted.

Action

Please remove and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3753	Mike	DSB3006B	Dental Sciences Building	Microbiology & Immunology

Description of Violation

Please review storage in flammable storage cabinet. Flammable waste stored and strong odour.

Action

Please purge waste and leaking and no longer required chemicals.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3754	Mike	SDRI 208	Siebens Drake Research Institute	Microbiology & Immunology

Description of Violation

Items stored on top of centre cupboard unit. Piled too high. A minimum of 18" clearance must be maintained for sprinkler effectiveness.

Action

Please correct

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3755	Mike	SDRI203	Siebens Drake Research Institute	Microbiology & Immunology

Description of Violation

Acetic acid incorrectly stored in Acid cabinet. Should be stored in Flammable storage cabinet.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3756	Mike	SDRI215	Siebens Drake Research Institute	Microbiology & Immunology

Description of Violation

Chemicals are not all labelled with a proper chemical name. All chemicals must be labelled.

Action

Please ensure all chemicals are labelled. Review inventory.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3757	Mike	SDRI230	Siebens Drake Research Institute	Microbiology & Immunology
Description of Violation			Action			
Base stored in Flammable Storage Cabinet with flammables. Should be stored with bases.			Please review chemical storage. Correct.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3758	Mike	SDRI230	Siebens Drake Research Institute	Microbiology & Immunology
Description of Violation			Action			
Caboy not labelled.			Please correct.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3759	Mike	SDRI 119.2	Siebens Drake Research Institute	Microbiology & Immunology
Description of Violation			Action			
Improper chemical storage. Many chemicals stored in fumehood. Fumehoods not to be used for storage.			Please review all chemical storage. Correct.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3760	Mike	SDRI118	Siebens Drake Research Institute	Microbiology & Immunology
Description of Violation			Action			
Extension cord used to power fridge. Extension cords not permitted.			Plug fridge directly into receptacle.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 11, 2012	Mar 21, 2012	2012-3761	Mike	SDRI 200/202	Siebens Drake Research Institute	Faculty of Medicine and Dentistry

Description of Violation

Many chemicals and samples left behind from vacated researcher. Includes chemical storage cabinets and refrigerators.

Action

Please purge all left over hazardous materials.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 12, 2012	Mar 22, 2012	2012-3762	Anne Marie	solvent dispensing R	Chemistry Building	Physical Plant - Caretaking

Description of Violation

Ladder stored against the wall in the in the solvent dispensing room

Action

Store the ladder in a secure manner

Comments

Complete 26/3/12

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 12, 2012	Mar 22, 2012	2012-3763	Anne Marie	030C	Chemistry Building	Physical Plant - Maintenance

Description of Violation

The electrical panel does not close

Action

Repair panel

Comments

W/O 199825

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 12, 2012	Mar 22, 2012	2012-3764	Anne Marie	003 and 202-203	Chemistry Building	Physical Plant - Caretaking

Description of Violation

Fire extinguisher not checked monthly
CHB 003 and 202-203

Action

Inspect the fire extinguisher

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 12, 2012	Mar 22, 2012	2012-3765	Anne Marie	124	Chemistry Building	Physical Plant - Maintenance

Description of Violation	Action
Shelves in the cabinet under the fumehood are rusted	Repair

Comments

Total Orders 193