

Compliance Orders Past Due as of Mar 27, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3605	Mike	LwH 2240	Lawson Hall	History

Description of Violation

Shelving frames leaning against wall. Could fall over.

Action

Please remove, install or secure. Contact Jeff Jones.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3604	Mike	LwH 2219	Lawson Hall	History

Description of Violation

Shelving frame leaning against wall. Could fall over.

Action

Please remove, install or secure. Contact Jeff Jones.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3603	Mike	LwH 2270A	Lawson Hall	History

Description of Violation

Old metal shelving laying on floor just inside doorway. Presents a trip hazard.

Action

Please remove from doorway and store safely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3640	Mike	PAB146	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Jug of alcohol sitting precariously on materials in room. Must be stored securely in an approved flammable storage cabinet.

Action

Please remove immediately and store in approved flammable storage cabinet. Please also have staff member enroll in, and complete Laboratory and Environmental Safety course offered through OHS.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3649	Mike	BGS0127	Biological & Geological Sciences	Earth Sciences

Description of Violation

Railing/barrier must be installed around pit immediately to prevent accidental fall and injury.

Action

Please install barrier immediately. Rope/chain off area. Post signs. Contact Facilities Management to ensure railing meets code.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 20, 2012	Feb 28, 2012	2012-3645	Mike	BGS1060	Biological & Geological Sciences	Earth Sciences

Description of Violation

Labelled flammable storage cabinet used to store bases.

Action

Please relabel cabinet as to correct contents. Label clearly "BASES".

Comments

Total Orders Past Due 6