

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4103	Mike	Back room	Books Plus	Books Plus

Description of Violation

Large stepladder leaning upright against wall, untethered. Could fall over.

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4104	Mike	FEB1138	Faculty of Education Building	Fire Safety - CCPS

Description of Violation

Fire extinguisher sitting on floor. No wall bracket.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4105	Mike	Pharmacy Area	Books Plus	Fire Safety - CCPS

Description of Violation

Fire extinguisher sitting on floor. No wall bracket.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 23, 2012	Nov 2, 2012	2012-4106	Mike	chnical Area (Ca	Elborn College	Library Information Services

Description of Violation

Accumulation of E-Waste piled and blocking aiseways.

Action

Please use empty E-Waste bin (blue) that is sitting empty and ready to organize area.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 23, 2012	Nov 2, 2012	2012-4107	Mike	EC1160	Elborn College	Library Information Services

Description of Violation

Buildup of combustibles in large storage area. Many bags of crumpled newsprint.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 23, 2012	Nov 2, 2012	2012-4108	Mike	EC2528	Elborn College	Communication Sciences and Disorders

Description of Violation

Extension cords in use and daisy chained. Extension cords not permitted.

Action

Please remove. Plug directly in to wall outlet or, if necessary, use power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 23, 2012	Nov 2, 2012	2012-4109	Mike	EC1458	Elborn College	Physical Therapy

Description of Violation

All kitchen appliances are not plugged directly into wall receptacle. High current devices may not be plugged in through a power bar.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4110	Mike	loading dock area out	Essex Hall Residence	sp. Services - Residence Operations

Description of Violation

Loading dock area needs a number of improvements to be addressed.
 1. Skid on side unsecured
 2. Milk crates piled at top of stairs narrowing passageway.
 3. Not all propane tanks stored in cage. Some outside on dock area.
 4. Smokers area not the required 10m from entranceway.

Action

Please correct by
 1. Securing skid OR laying down OR removing.
 2. Store milk crates so egress in not impeded.
 3. Ensure all propane tanks secured in cage.
 4. Employees who smoke must be 10m from entrance (note also that propane storage is close by)

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4111	Mike	ception/Front off	London Hall Residence	Housing & Ancillary Services

Description of Violation

First aid kit has been checked yearly (just before annual inspection) and not monthly as required.

Action

Please check monthly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4112	Mike	ont office/receptio	Perth Hall Residence	Housing & Ancillary Services

Description of Violation

First aid kit a front desk/reception has not been checked monthly (or at all) and white tag filled out.

Action

Please check monthly and complete tag.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4113	Mike	Student Council	Perth Hall Residence	Housing & Ancillary Services

Description of Violation

Residence Student Council room has a number of free standing plastic shelving units that are not secured to wall to prevent from falling over. Some units are already secured.

Action

Please secure the units that have not yet been secured.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4114	Mike	LB1A	Law Building	Law Library

Description of Violation

Some of Prof Kostals items (boxes of documents) have migrated back in to storage among the stacks. They were removed previously. Present egress hazard and build up of combustibles.

Action

Please remove AGAIN.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4115	Mike	LB 1A	Law Building	Faculty of Law

Description of Violation

Numerous items are stored among the stacks. They include, shelving, desks, furniture, etc. Pathways must be kept clear for egress.

Action

Please remove or store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4116	Mike	lway outside LB	Law Building	Faculty of Law

Description of Violation

Green filing cabinet with orange interior is stored in hallway.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4117	Mike	LB37	Law Building	Faculty of Law

Description of Violation

Folding table stored upright in hallway leaning against wall. Could fall over. Should be secured.

Action

Please tether or remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 29, 2012	Nov 8, 2012	2012-4118	Mike	UC 324A	University College	Faculty of Arts

Description of Violation

Solvent storage cabinet was written up last year because original latch assembly had been removed. Rather than original latch assembly being replaced to return cabinet to original "approved and certified" condition a sliding bolt was installed. This does not meet certification or secure doors properly.

Action

Please install original latch assembly OR purchase new cabinet OR dispose of all flammables (paint, etc). Alternate suggested by faculty to use another sliding bolt, or two (one on each door) vertically to ensure doors are secure is acceptable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4119	Mike	EIHR	Elgin Hall Residence	Housing & Ancillary Services

Description of Violation

Storage/staging of many boxes of printed material (brochures, handbooks, info, etc) in hallway outside EIHR 102L. Present an egress hazard and fire load.

Action

Please remove and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4120	Mike	R 105 (Front De	Elgin Hall Residence	Housing & Ancillary Services

Description of Violation

Fire Safety now requires high current kitchen appliances to be plugged directly into wall outlet rather than using a power bar. Microwave, kettle, coffee maker plugged into power bar.

Action

Please reorganize appliances so that kitchen appliances are plugged directly into wall outlet. Other items nearby such as radio, printer etc. may use a power bar. Contact Frank Faroni , Fire Safety, at 88266 if further direction is required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4121	Mike	EIHR 38C	Elgin Hall Residence	Physical Plant - Caretaking

Description of Violation

High current kitchen appliances such as microwave, kettle, etc are plugged into multi-tap. According to Fire Safety these must be plugged directly into wall socket.

Action

Please plug in directly. Contact Frank Faroni , Fire Safety, at 88266 if further direction is required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4122	Mike	EIHR 3D	Elgin Hall Residence	sp. Services - Residence Operatio

Description of Violation

In storage area new plastic shelves have been installed but security brackets from previous shelves are now in wrong place and do not secure new shelves.

Action

Please secure.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4123	Mike	HR - Paper Storage	Elgin Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
Step ladder/stool is not available in Paper Storage room.				Please purchase/place good stool in room.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4124	Mike	Sydenham T004	Sydenham Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
Shelf in storage area is not secured to wall AND has been broken and is 'repaired' with tape.				Supervisor indicated shelf in no longer required and will be removed and disposed of (so it can't be used elsewhere).		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4125	Mike	loading dock area	Sydenham Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
Small gas cylinders in loading dock area all unsecured/tethered. Chain is provided but not in use.				Please use provided chain to tether.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4126	Mike	Kitchen area	Sydenham Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
Eye wash has not been checked weekly and tag completed.				Please check.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4127	Mike	Kitchen area	Sydenham Hall Residence	sp. Services - Residence Operatio

Description of Violation

Eyewash location label has worn off.

Action

Please replace. Consider higher location away from wet environment.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4128	Mike	Student Council	Medway Hall Residence	Housing & Ancillary Services

Description of Violation

In Student Council Beer Can Storage room an extension cord is in use. Extension cords not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4129	Mike	Delaware GC13	Delaware Hall Residence	Housing & Ancillary Services

Description of Violation

Extension cord in use to power computers.

Action

Please remove extension cord and either plug directly into wall outlet or use a power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4130	Mike	loading Dock area	Delaware Hall Residence	sp. Services - Residence Operatio

Description of Violation

In loading dock area there is a wooden skid sitting upright, untethered beside milk crates. Should be securely tethered to prevent from falling over.

Action

Please remove or tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4131	Mike	SC1224 Hallway	Social Science Centre	Psychology

Description of Violation

Surplus bookshelves free standing in hallway. Not secure.

Action

Please secure or remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4132	Mike	SSC9238	Social Science Centre	Psychology

Description of Violation

Unlabelled chemicals in lab including inside flammable storage cabinet and squeeze bottle.

Action

Please label wth WHMIS labels.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4133	Mike	SSC9238	Social Science Centre	Psychology

Description of Violation

Electrical cord running above ceiling tiles.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4134	Mike	SSC9238	Social Science Centre	Psychology

Description of Violation

Evidence of food and drink in lab where hazardous materials are used.

Action

Please do not eat and drink in lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4135	Mike	SSC9214A	Social Science Centre	Psychology

Description of Violation

Small gas cylinder is not tethered.

Action

Please secure.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4136	Mike	SSC9214	Social Science Centre	Psychology

Description of Violation

Ethanol labelled as "EtOH" Requires full chemical name on a WHMIS label.

Action

Please correctly label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4137	Mike	SSC9215	Social Science Centre	Psychology

Description of Violation

Proper WHMIS labels with full chemical name missing from "1:2 HCl" and on caboys labelled as "dH2O".

Action

Please label using WHMIS labels with full chemical name.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4138	Mike	SSC8440A	Social Science Centre	Psychology

Description of Violation

No 'yellow' Laboratory Hazard sign on door.

Action

Please complete and post signage.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4139	Mike	SSC8237A	Social Science Centre	Psychology

Description of Violation

Not all chemical are labelled with full chemical name.

Action

Please affix WHMIS label with full chemical name and details.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4140	Mike	SSC7206	Social Science Centre	Psychology

Description of Violation

Long ethernet cable draped across floor and tangled in chair legs. Trip/catch hazard.

Action

Please secure ethernet cable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 6, 2012	Nov 15, 2012	2012-4141	Mike	SSC8440A	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Ceiling tile missing from area around heat detector. Tile will need a hole carved out to accommodate detector. Appears detector installed and tile never replaced.

Action

Please replace tile.

Comments

Work order 221530 was created for this safety compliance order.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4142	Mike	storeroom LH147	Lambton Hall	sp. Services - Residence Operatio

Description of Violation

Storage room has many paint cans and items on floor and into egress routes. Presents possible trip hazard and ergonomic difficulty for shelving and unshelving materials.

Action

Clear aisleways. Store paint off floor.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4143	Mike	Basement Hallway	Saugeen Maitland Hall Residence	Physical Plant - Caretaking
Description of Violation				Action		
SAME AS LAST YEAR. Old bifold doors that have been removed from closets are standing upright in hallway and are not secured. Bedssprings also. Could fall over and block egress.				Please tether.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4144	Mike	ht office SMHR10	Saugeen Maitland Hall Residence	Housing & Ancillary Services
Description of Violation				Action		
The staff/employee first aid kit (as distinct from the student one) has not been checked monthly, tag filled out and first aid rep's card displayed.				Please check and display certification card.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4145	Mike	Kitchen	Saugeen Maitland Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
Shelf to store plastic supplies, beside door into servery, is very wobbly and should be secured to wall. Wooden skids, on their edge, are leaning unsecured to the unsecured shelf. Poor arrangement.				Please secure shelf. Store wooden skids elsewhere. Tether skids if stored on edge.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4146	Mike	ack Bar - SMHR	Saugeen Maitland Hall Residence	sp. Services - Residence Operatio
Description of Violation				Action		
In the old, unused snackbar, many boxes are piled high and are not secure. Could easily topple over.				Please correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4147	Mike	Outside 120	Graphic Services Building	Physical Plant - Caretaking

Description of Violation

Eyewash in hallway of Graphics (outside room 120) has not been checked weekly and blue tag filled out.

Action

Please add this eyewash to the list to be checked weekly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 10, 2012	Nov 19, 2012	2012-4148	Mike	Hallway by cages	Graphic Services Building	Physical Plant - Maintenance

Description of Violation

SAME AS LAST YEAR. Many items stored in hallway of Graphics Building. Includes untethered doors and skid, van seat, boxes, etc.

Action

Same problem as last year. Ken Hill was successful in getting area cleared however problem has reappeared since his work. Please remove all items. Facilities Management to please develop, document and monitor a system that ensure items are not stored/left/staged in hallway.

Comments

Work order 221534 was created for this safety compliance order.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 11, 2012	Nov 20, 2012	2012-4149	Mike	ycling Loading D	Graphic Services Building	Physical Plant - Maintenance

Description of Violation

First Aid Kit beside the loading dock for the workers at the Western Recycling Center has not been checked monthly and white tag completed. A copy of the certificate of First Aid rep for area must also be displayed.

Action

Please ensure one of the workers at Western Recycling is trained and posts his certificate. That designated worker should also check the kit monthly.

Comments

Work order 221594 was created for this safety compliance work order

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 13, 2012	Nov 22, 2012	2012-4150	Mike	VAC230B/230C	Visual Arts Centre	Visual Arts

Description of Violation

Red can for rags is overflowing and lid will not close. In both VAC230B and VAC230C.

Action

Please ensure cans are emptied when full.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 13, 2012	Nov 22, 2012	2012-4151	Mike	Chemical HazMa	Visual Arts Centre	Visual Arts

Description of Violation

Old CRT TV is stored in chemical HazMat facility.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 13, 2012	Nov 22, 2012	2012-4152	Mike	MC351 - Mudville	Middlesex College	Computer Science

Description of Violation

Storage cabinet very tippy. Levelling feet have not been adjusted and all appear to be in their fully retracted position.

Action

Please adjust levelling feet so cabinet is stable.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 13, 2012	Nov 22, 2012	2012-4153	Mike		Middlesex College	Mathematics

Description of Violation

First Aid kit has not been checked monthly and tag filled out. First Aid rep certificate on kit has expired.

Action

Please appoint a new Faculty/Staff member to be First Aid certified. Please check kit monthly. Call Shauntel at 80315 to register for the next First Aid course (free) and to obtain any first aid supplies needed to replenish kit. Hang kit when renovations complete.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4154	Mike	SSC4049	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Ceiling tile missing. Occupants concered since they know the building has asbestos in places.

Action

Please replace ceiling tile.

Comments

WO 223094

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4155	Mike	SSC4070	Social Science Centre	Fire Safety - CCPS

Description of Violation

Storage room has no heat detector. No sure if one is required.

Action

Please investigate and take whatever action Fire Safety determines is appropriate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4156	Mike	C4061 (Classroo	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Vinyl baseboard peeling off wall. Possible trip hazard.

Action

Please repair.

Comments

WO 223098

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4157	Mike	ll outside SSC40	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Vinyl baseboard peeling off wall. Possible trip hazard.

Action

Please repair.

Comments

WO 223099

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4158	Mike	SSC4434	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Quadraplex receptacle on south wall of room SSC4434 has a badly broken cover plate and hole in drywall is cut too large for standard cover plate. Pieces missing from cover plate.

Action

Please repair.

Comments

WO 223108

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4159	Mike	SSC4434	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Ceiling tile missing. Occupants concerned knowing asbestos in areas of building.

Action

Please replace.

Comments

WO 223105

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4160	Mike	SSC4152	Social Science Centre	Physical Plant - Maintenance

Description of Violation

Undersized plastic lens is still in office of the Chair of Political Science. Falls down periodically. Right over his desk chair and sitting position.

Action

All the undersized lenses in Social Science Centre that were falling down (because they are undersized) were determined years ago to be a significant safety hazard and were to all have been replaced. It is a large building and it appears some may have been missed. Please, in addition to the lens(es) in this order, audit the whole building to ensure all others have been replaced.

Comments

WO 223107

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4161	Mike	SSC4226	Social Science Centre	Political Science

Description of Violation

THIS ORDER WAS WRITTEN UP PREVIOUSLY (Dec 10, 2010). File boxes and other materials are stored in aiseways among the stacks of the Multi Governance Lab. Present trip and access hazard and could topple over.

Action

Please correct again.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 14, 2012	Nov 23, 2012	2012-4162	Mike	SSC3419	Social Science Centre	Anthropology

Description of Violation

Computer beside door plugged into power bar that is daisy chained with an extension cord. Extension cords not permitted. Daisy chaining not permitted.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4163	Mike	TRAC 185	TRAC	TRAC

Description of Violation

In the Community Storage Room there are a number off tall standards and pole vault equipment that is stored improperly. Long items resting against wall should be tethered.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4164	Mike	TRAC 181	TRAC	TRAC

Description of Violation

Untethered ladder stored, leaning against wall. Could fall over.

Action

Please store properly. Tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4165	Mike	TRAC 181	TRAC	TRAC

Description of Violation

Guard has been removed from grinder.

Action

Please reinstall guard.
Instruct users on proper operation.
Set up a regular inspection program and document.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4166	Mike	TRAC 181	TRAC	TRAC

Description of Violation

A broken plexiglass panel with sharp edges is leaning, unsecured against a wall in a pathway.

Action

Please remove and store securely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4167	Mike	South Stairway TRAC	TRAC	TRAC

Description of Violation

A bucket is on the steps on the south staircase of TRAC to catch water from leak. Stairs must be kept clear.

Action

Repair leak so that bucket is not needed on stairs. If Facilities Management is unable to fix leak please ask them to consider a temporary repair the does not require anything on the stairway but also collects water to prevent a slip hazard.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4168	Mike	WSRC4226	Western Student Recreation Centre	Physical Plant - Maintenance

Description of Violation

The vinyl baseboard has become unglued and now presents a trip hazard.

Action

Please recement/glue to wall.

Comments

WO 223091

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4169	Mike	WSRC2222	Western Student Recreation Centre	Campus Recreation

Description of Violation

Paddles stored/stuffed behind entrance door, untethered. Door cannot open fully and paddles fall over.

Action

Store securely elsewhere.

Comments

WO 223092

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4170	Mike	WSRC Loading Dock	Western Student Recreation Centre	Campus Recreation

Description of Violation

Loading dock and loading dock entrance area needs to be kept clear of items and should not be used for storage. Surplus flooring and skids must be tethered.

Action

Please correct. Use empty shelving to store items properly. Some items on loading dock may belong to TRAC. Work with TRAC for cleanup of materials.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4171	Mike	TDW 108A	TD Waterhouse Stadium	Campus Recreation

Description of Violation

Projector suspended from ceiling is powered using an extension cord (yellow). Extension cords not permitted.

Action

Please power using the receptacle adjacent to the projector, on the ceiling, that has been provided for that purpose.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4172	Mike	Pride Library	Weldon Library	Pride Library

Description of Violation

Many boxes are stored at entrance way and in aiseways preventing easy access and egress. Piled high. Other items stored at the end of aisles.

Action

Please remove items and clear pathways. Signs on some items read "to be catalogued". If project completion is not in near future arrangement should be made to store items elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4173	Mike	Gov't Pub Area	Weldon Library	Physical Plant - Maintenance

Description of Violation

Light fixtures falling off wall. On NW end of Government Publications room near Range 23.

Action

Please correct. See Richard Kirk for exact location.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 24, 2012	Dec 3, 2012	2012-4174	Mike	ARC	Weldon Library	Weldon Library

Description of Violation

Skids stored upright (plastic and wooden) in charging area. Should be tethered to prevent from falling over.

Action

Please tether or remove.

Comments

Total Orders 599