

Compliance Orders Past Due as of Dec 5, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 31, 2012	Jul 10, 2012	2012-4078	Mike	est 2/3 of new sh	onmental Science Western Field St	Biology

Description of Violation

New storage (2/3 west section used by Biology) needs organization. Trip and fall hazards present. Boxes stacked.

Action

Please organize. Told that shelving is planned to be installed by Department of Biology soon. Please install. Consider reducing inventory by purging materials no longer needed.

Comments

October 3rd as per Peter Duenk - "We are in the process of getting quotes to supply and install cages to contain the items in question. We have already installed one cage for field trip equipment."
November 1st - Discussed by phone with Hugh Henry. Project underway. Should be completed by month end. Will let Mike know.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4103	Mike	Back room	Books Plus	Books Plus

Description of Violation

Large stepladder leaning upright against wall, untethered. Could fall over.

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4100	Mike	airway to FEB20	Faculty of Education Building	Physical Plant - Maintenance

Description of Violation

Lighting not working on stairs leading to mezzanine. Bulbs in place. Dark.

Action

Please repair.

Comments

WO 218814

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4097	Mike	FEB2038	Faculty of Education Building	Faculty of Education

Description of Violation

Long signal cable draped loosely across traffic area.

Action

Please reroute and secure. Suggest along baseboard and behind seating.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4095	Mike	050 (Auditorium)	Faculty of Education Building	Faculty of Education
Description of Violation				Action		
Two cans of black, oil based (hence flammable) oil bases paint stored in the open on stage.				Please remove and store in an approved, flammable storage cabinet.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4093	Mike	1054 (Music Ro	Faculty of Education Building	Faculty of Education
Description of Violation				Action		
Electrical problems. Extension cord in use, Daisy chaining. Multitap in use.				Please have FE install sufficient outlets in location adjacent to items requiring power.		
Comments						
WO 223178						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4092	Mike	FEB2063	Faculty of Education Building	Faculty of Education
Description of Violation				Action		
Old, abandoned fridge is in poor condition. Moldy inside.				Please repair and clean or discard.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4090	Mike	FEB1100	Faculty of Education Building	Faculty of Education
Description of Violation				Action		
Extension cord in use. Line cord draped across floor after exiting cupboard. Presents trip and electrical hazard.				Please correct by installing a new duplex receptacle at new location on wall behind lecturn.		
Comments						
THIS DEFICIENCY HAS BEEN WRITTEN UP FOR THE LAST THREE YEARS. THE HAZARD REMAINS. October 24 -Work order 218741 was created for this safety compliance order.						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 14, 2012	Oct 24, 2012	2012-4084	Mike	FEB1048	Faculty of Education Building	Faculty of Education
Description of Violation				Action		
Dividers, artwork, boards, etc leaning against cage, untethered. Could fall over and present egress hazard.				Please remove from hallway OR tether securely.		
Comments						
WO 223211						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Nov 23, 2012	Nov 2, 2012	2012-4106	Mike	chnical Area (Ca	Elborn College	Library Information Services

Description of Violation

Accumulation of E-Waste piled and blocking aisleways.

Action

Please use empty E-Waste bin (blue) that is sitting empty and ready to organize area.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4128	Mike	y Student Council	Medway Hall Residence	Housing & Ancillary Services

Description of Violation

In Student Council Beer Can Storage room an extension cord is in use. Extension cords not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Dec 3, 2012	Nov 12, 2012	2012-4121	Mike	EIHR 38C	Elgin Hall Residence	Physical Plant - Caretaking

Description of Violation

High current kitchen appliances such as microwave, kettle, etc are plugged into multi-tap. According to Fire Safety these must be plugged directly into wall socket.

Action

Please plug in directly. Contact Frank Faroni , Fire Safety, at 88266 if further direction is required.

Comments

Total Orders Past Due 12