

Compliance Orders

Status as at February 22, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3573	Mike	C134 (rear area)	Talbot College	Physical Plant - Maintenance

Description of Violation

Tile flooring under mobile shelving is loose, curling and lifting. Presents possible slip/trip to users.

Action

Please repair 'bad' tiles. Was told that this area was due to be renovated but underbudgeting has resulted in significant postponement. Hence repair in the meantime is advised.

Comments

WO 193759

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3574	Mike	llway outdie TC3	Talbot College	Physical Plant - Maintenance

Description of Violation

UWO Mailbox in hallway outside TC316 has unlocked main door. Swings into hallway and could catch people walking down hall.

Action

Please secure closed. Suggest Mailroom personal (who have necessary keys) relock/secure. If lock is broken Lockshop may need to be involved.

Comments

WO 193762

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3575	Mike	TC302	Talbot College	Faculty of Music

Description of Violation

Old, unused, CRT monitors stored on floor. Present possible trip/kick hazard.

Action

Please remove and/or store properly off the floor on shelves.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3576	Mike	TC22	Talbot College	Faculty of Music

Description of Violation

No First Aid kit in area.

Action

First Aid rep, Brian Hart, to contact Sintia in OHS @ 80315, to order kit. Brian to create First Aid station with his certificate, poster, etc.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3577	Mike	Loading Dock	Talbot College	Faculty of Music

Description of Violation

Ladder leaning against wall in loading dock area, unsecured. Could fall over.

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3578	Mike	104 'Green Roo	Talbot College	Faculty of Music

Description of Violation

Ancient, moldy, disrepaired, unused frdge in 'Green Room'. Presents health and possible fire/electrical hazard.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3579	Mike	way outside MB	Music Building	Faculty of Music

Description of Violation

Hallway outside MB206. Old lockers placed in hallway. Unsecured, could fall over. Very messy area. Many items on floor present trip hazard.

Action

Contact Fire Safety to see if lockers permitted, otherwise remove. If permitted contact Facilities Engineering to secure. Ensure area kept tidy.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3580	Mike	MB113	Music Building	Faculty of Music

Description of Violation

Hallway outside MB206 has many items stored and left behind (such as old rack, stools, etc). Hallway must be kept clear.

Action

Please remove and keep clear at all times. Told that the 'percussion people' are messy and will not keep area clean. PLEASE ENFORCE.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3581	Mike	3rd floor student lab	Music Building	Faculty of Music

Description of Violation

Microwave sitting high on top of cabinet not secured above bannister. Could fall off, over edge to floor below.

Action

Remove and relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3582	Mike	1B102 Classroom	Music Building	Physical Plant - Maintenance

Description of Violation

Cover missing off duplex receptacle, near entrance, to classroom.

Action

Please repair

Comments

WO 193757

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 9, 2012	Jan 19, 2012	2012-3583	Mike	Stairs	Psyc House @ 363 Windermere	Psychology

Description of Violation

Snow boots left on landing at top of stairs. Presents trip hazard.

Action

Remove. Designate a spot, away from the stairs, where boots can be left. Signage in the area should point out to visitors, and occupants that there is a safe designated place.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 9, 2012	Jan 19, 2012	2012-3584	Mike	1st Steps and Wa	Psyc House @ 363 Windermere	Physical Plant - Maintenance

Description of Violation

Front, outside steps uneven, sloped, with no handrail. Employee has slipped and questions condition and compliance with code.

Action

Please investigate. Consider condition and possible solutions. Determine whether meets standards/code. Please report back to Mike Mosley so he can update tenants.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 9, 2012	Jan 19, 2012	2012-3585	Mike	Call Centre	Call Centre @ 367 Windermere	Development

Description of Violation

First Aid kit is in Call Centre but requires
 1. Trained Rep with certificate posted
 2. Inventory tag filled out monthly
 3. First Aid poster 1101
 4. Visible location

Action

Please call Sintia in Health and Safety @ 80315 to arrange for staff member to receive First Aid training and be the First Aid Rep for the area.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 9, 2012	Jan 19, 2012	2012-3586	Mike	NCB439	North Campus Building	Faculty of Information and Media Stud

Description of Violation

Masters Student Lounge has combustibles (boxes, books, etc) piled up beside refrigerator. Restricts flow and provides fuel in case of overheating and fire.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3587	Mike	Ivey 2G25	Ivey School of Business Administration	Ivey School of Business

Description of Violation

SAME VIOLATION AS WAS WRITTEN UP LAST YEAR. The First Aid kit in 2G25 has not been checked monthly and tag initialed. Reps names no longer posted (Castillo, Johnston, Woytaz).

Action

Please have the reps (Castillo, Johnston, Woytaz) check monthly and display their certificates.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3588	Mike	Lower stacks.	Ivey School of Business Administration	Bud Johnston Library

Description of Violation

Furniture (desk return) stored in aisleways in stacks.

Action

Please store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3589	Mike	Ivey 3B11	Ivey School of Business Administration	Ivey School of Business

Description of Violation

SAME ORDER AS WAS WRITTEN UP LAST YEAR. Boxes in storage piled high and stacked poorly. Could fall over.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3590	Mike	MC344A	Middlesex College	Computer Science

Description of Violation

Boxes stacked poorly. Could fall over.

Action

Please organize and store securely.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3591	Mike	MC327A	Middlesex College	Computer Science

Description of Violation

Extension cords in use. Extension cords not permitted.

Action

Please remove. Consider plugging in directly or use power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3592	Mike	MC327B	Middlesex College	Computer Science

Description of Violation

Signal cables draped across floor/pathway. Presents trip hazard.

Action

Please remove and reroute.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3593	Mike	MC327	Middlesex College	Computer Science

Description of Violation

Phone cord draped across floor to centre table. Trip hazard.

Action

Remove. Consider hanging phone on wall or have cable drop installed in area of centre table.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3594	Mike	MC13	Middlesex College	Computer Science

Description of Violation

Extension cords in use. Numerous trip hazards on floor. Build up of combustibles.

Action

Remove extension cords. Organize and purge room.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3595	Mike	MC14	Middlesex College	Computer Science

Description of Violation

Unsecured shelf. Boxes piled on top.

Action

Please secure shelf. Remove items from top shelf.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 13, 2012	Jan 23, 2012	2012-3596	Mike	MC210	Middlesex College	Applied Mathematics

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove. Consider substituting power bar or plug in directly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3597	Mike	StvH3130	Stevenson Hall	Philosophy

Description of Violation

First Aid Station needs updating. Kit to be placed on shelf in kitchenette, certificate of trained rep display, first aid poster hung and monthly checking completed.

Action

Please correct. For supplies and details contact Sintia in OHS at extention 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3598	Mike	LwH 2201	Lawson Hall	History

Description of Violation

First Aid Station needs updating. Certificate of trained rep displayed, first aid poster hung and monthly checking completed.

Action

Please correct. For supplies and details contact Sintia in OHS at extention 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3599	Mike	LwH 3203	Lawson Hall	Classical Studies

Description of Violation

First Aid Station needs updating. Certificate of trained rep displayed, first aid poster hung, and monthly checking completed.

Action

Please correct. For supplies and details contact Sintia in OHS at extention 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3600	Mike	LwH 3270B	Lawson Hall	Rhetoric and Professional Commu

Description of Violation

First Aid Station needs updating. Certificate of trained rep displayed, first aid poster hung, and monthly checking completed.

Action

Please correct. For supplies and details contact Sintia in OHS at extention 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3601	Mike	StvH3130A	Stevenson Hall	Philosophy

Description of Violation

Sturdy steep ladder/stool not available in library area to reach higher shelves.

Action

Please make available.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3602	Mike	StvH2138	Stevenson Hall	Philosophy

Description of Violation

Storage room has a number of concerns. No stool/ladder available to reach higher shelves, build up of combustibles (boxes), items prevent egress and present trip hazard.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3603	Mike	LwH 2270A	Lawson Hall	History

Description of Violation

Old metal shelving laying on floor just inside doorway. Presents a trip hazard.

Action

Please remove from doorway and store safely elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3604	Mike	LwH 2219	Lawson Hall	History

Description of Violation

Shelving frame leaning against wall. Could fall over.

Action

Please remove, install or secure. Contact Jeff Jones.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3605	Mike	LwH 2240	Lawson Hall	History

Description of Violation

Shelving frames leaning against wall. Could fall over.

Action

Please remove, install or secure. Contact Jeff Jones.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3606	Mike	StvH 3130	Stevenson Hall	Fire Safety - CCPS

Description of Violation

Fire extinguisher sitting on floor.

Action

Please install bracket on wall and hang.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3607	Mike	LwH 2211	Lawson Hall	Fire Safety - CCPS

Description of Violation

Fire extinguisher sitting on floor.

Action

Please install bracket on wall and hang.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3608	Mike	WSS 121	Western Student Services	Western Student Services

Description of Violation

Same order as last year however some improvement apparent. Storeroom overcrowded and poor storage. Disorganized, egress route not clear. Trip hazard. No ladder for high storage. Access to shelves difficult.

Action

Please continue improvements. Arrange in a proper and safe manner. Appoint a person responsible for monitoring and correcting condition.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3609	Mike	WSS 2129	Western Student Services	Western Student Services

Description of Violation

First Aid kit has not been checked monthly and white tag filled out.

Action

Please check monthly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 20, 2012	Jan 30, 2012	2012-3610	Mike	WSS 4146	Western Student Services	Western Student Services

Description of Violation

First Aid kit has not been checked monthly and white tag filled out. Certificate indicates that Brent has expired.

Action

Please affix Brent's current certificate or have Brent retrained. Brent to check monthly and fill out white tag. Contact Sintia in OHS at 80315 if Brent needs updating.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 21, 2012	Jan 31, 2012	2012-3611	Mike	TL 170	Taylor Library	Taylor Library

Description of Violation

Extension cord used to deliver power to work station. Extension cords not permitted.

Action

Please remove. Replace with power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 21, 2012	Jan 31, 2012	2012-3612	Mike	UCC 234A	University Community Centre	Western Student Services

Description of Violation

First Aid Station in Student Success Centre needs attention.
 1. No trained First Aid rep poster
 2. Poster not displayed
 3..Monthly check not completed.

Action

Please review and update. Contact Sintia at 80315 in OHS for supplies and information.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 21, 2012	Jan 31, 2012	2012-3613	Mike	Bookstore	University Community Centre	Bookstore

Description of Violation

Extension cord in use to power fan by cashiers.

Action

Please remove. Consider using power bar instead.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 21, 2012	Jan 31, 2012	2012-3614	Mike	Office Suite	University Community Centre	Bookstore

Description of Violation

Monthly checklist of First Aid Kit has not been carried out, and tag filled out, since October.

Action

Please check monthly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3615	Mike	HSB315	and Sonia Labatt Health Sciences B	Faculty of Health Sciences

Description of Violation

Items stored/left in hallway. Items tagged to be retained. Hallways are to be keep clear. Storage not permitted.

Action

Please remove and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3616	Mike	HSB 344A	and Sonia Labatt Health Sciences B	Ivey School of Business

Description of Violation

First Aid Station has a number of deficiencies. Kit has not had monthly check and tag filled out since 2006. Kit missing copy of First Aid certificate for first aid rep. First Aid poster not supplied.

Action

Please correct. Any necessary supplies can be obtained in OHS from Sintia @ 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3617	Mike	HSB416, HSB417	and Sonia Labatt Health Sciences Bldg	Biology

Description of Violation

Laboratory Hazard signs (yellow) and PPE signs (safety glasses) remain affixed to doors even though Biology has vacated area. Signs were originally installed by Department of Biology.

Action

Please remove. Consider using a heat gun to 'loosen' adhesive to make removal much easier (and not damage door).

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3618	Mike	Loading dock	and Sonia Labatt Health Sciences Bldg	Physical Plant - Caretaking

Description of Violation

Wooden pallet sitting upright on loading dock. Pallets must either be secured (chained) if stored upright or set down flat. This is to prevent falling over.

Action

Please correct. It is understood that the building has many tenants and that it may not have been left by FM Caretaking. It is appreciated if FM Caretaking could coordinate removal.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3619	Mike	HSB 28 - Storage	and Sonia Labatt Health Sciences Bldg	Hospitality Services - Cash Operations

Description of Violation

Two upright shelf units (chrome) and not secured to wall and could fall over if not loaded properly or bumped.

Action

Please secure to wall.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3620	Mike	AH11	Alumni Hall	Physical Plant - Maintenance

Description of Violation

Ceiling diffuser covered with duct tape. Restricts air exchange and may affect air quality.

Action

Please investigate and correct as necessary.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3621	Mike	ens Basketball R	Alumni Hall	Faculty of Health Sciences

Description of Violation

Extension cord in use to power TV. Extension cords not permitted.

Action

Please remove extension cord. Consider either using a power bar or have an outlet installed near TV (and away from shower).

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 23, 2012	Feb 2, 2012	2012-3622	Mike	Stage area	Alumni Hall	Faculty of Health Sciences

Description of Violation

Numerous 'sports' items left, disorganized, on stage (volleyball net, etc). Presents a trip hazard (especially in dark stage area).

Action

Please remove and store properly. Monitor usage and ensure compliance.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3623	Mike	TH2225	Thames Hall	Kinesiology

Description of Violation

Extensio cords in use in Main Office area.

Action

Please remove and replace with power bars.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3624	Mike	Various	3M Centre	Fowler- Kennedy

Description of Violation

Extension cords are being used in various locations (ie offices, counters). Extension cords not permitted.

Action

Please remove and replace with power bars.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3625	Mike	TH2165	Thames Hall	Kinesiology

Description of Violation

Numerous bottles of waste chemicals in the lab (darkroom for example).

Action

Please purge/minimize chemical waste.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3626	Mike	TH2165	Thames Hall	Kinesiology

Description of Violation

A number of containers containing chemicals are not labelled.

Action

Please ensure ALL chemicals are labelled with proper chemical names.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3627	Mike	TH3170	Thames Hall	Kinesiology

Description of Violation

First Aid kit has not been checked monthly, as required, by designated First Aid rep for the department.

Action

Please check monthly and complete inventory tag.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3628	Mike	TH4110	Thames Hall	Kinesiology

Description of Violation

Storage room very disorganized. Boxes piles high and not securely.

Action

Please organize boxes and store securely. Consider purging unnecessary materials.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3629	Mike	SH2302	Somerville House	Kinesiology

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove. Replace with power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3630	Mike	SH2345	Somerville House	re for the Study of Theory and Crit

Description of Violation

First aid kit has not been checked monthly and inventory card filled out by first aid rep, First aid reps certificate not displayed. First aid poster not displayed.

Action

Please correct. Any necessary materials are available from OHS. Call Sintia at 80315 with assistance.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3631	Mike	#1335 'The Bunk	Somerville House	re for the Study of Theory and Crit

Description of Violation

Extension cords in use in the 'bunker'. Large orange extension cord and various others delivering power to carrels. Extension cords not permitted. Also presents trip hazard.

Action

Please remove and replace with power bars. Please check area regularly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 27, 2012	Feb 6, 2012	2012-3632	Mike	Lucys	Somerville House	ospitality Services - Cash Operatio

Description of Violation

First aid kit has not been checked since November and white tag filled out.

Action

Please check monthly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 8, 2012	Feb 16, 2012	2012-3633	Mike	SSB3300	Support Services Building	Information Technology Services

Description of Violation

Free standing bookshelf adjacent to emergency exit not secured and could fall over blocking egress.

Action

Please either secure to wall or relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 8, 2012	Feb 16, 2012	2012-3634	Mike	All	Support Services Building	Physical Plant - Maintenance

Description of Violation

Shop inspection checklists not up to date. Some are current however some were last done in 2006.

Action

Please ensure inspections are up to date. Paul Martin, Tony Hammoud and Darryl Stanley (JOHSC rep) will check in early March and inspect all shops, stores, etc.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3635	Mike	PAB6	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

New eyewash station in machine shop needs to be inspected weekly by occupants and blue tag filled out.

Action

Please begin checking weekly. Affix blue tag to eyewash and complete. Blue tags may be obtained from OHS by calling Sintia @ 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3636	Mike	PAB6	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

First Aid Station does not have poster or copy of certificate of rep posted.

Action

Please update as required. Poster and monthly inventory tag (white) can be obtained from OHS by calling Sintia @ 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3637	Mike	PAB12	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Extension cord daisy chained into power bar from student desk. Extension cords not permitted. Daisy chaining not permitted. Presents trip hazard.

Action

Please remove extension cord. Route power bar so that it is not a trip hazard.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3638	Mike	PAB124	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

New supplies storeroom for Main Office has items stored on high shelves with no ladder or step stool present to reach items in a safe manner.

Action

Please obtain a robust, commercial quality stool/ladder to be kept readily available in the room for convenient use by office staff.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3639	Mike	PAB28	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Soreroom for Department has items stored on high shelves with no ladder or step stool present to reach items in a safe manner.

Action

Please obtain a robust, commercial quality stool/ladder to be kept readily available in the room for convenient use by Stores staff.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3640	Mike	PAB146	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Jug of alcohol sitting precariously on materials in room. Must be stored securely in an approved flammable storage cabinet.

Action

Please remove immediately and store in approved flammable storage cabinet. Please also have staff member enroll in, and complete Laboratory and Environmental Safety course offered through OHS.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Mar 14, 2012	Feb 22, 2012	2012-3641	Mike	PAB214	Physics & Astronomy Building	Physics & Astronomy

Description of Violation

Small, Canadian Tire branded, fridge in laboratory is not labelled.

Action

Please label as to class/type of contents. An inventory, affixed to the outside in advised.

Comments

Total Orders 69