

# Compliance Orders Past Due as of Feb 22, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3581	Mike	ld floor student l	Music Building	Faculty of Music

**Description of Violation**

Microwave sitting high on top of cabinet not secured above bannister. Could fall of, over edge to floor below.

**Action**

Remove and relocate.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3574	Mike	llway outdie TC3	Talbot College	Physical Plant - Maintenance

**Description of Violation**

UWO Mailbox in hallway outside TC316 has unlocked main door. Swings into hallway and could catch people walking down hall.

**Action**

Please secure closed. Suggest Mailroom personal (who have necessary keys) relock/secure. If lock is broken Lockshop may need to be involved.

**Comments**

WO 193762

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3575	Mike	TC302	Talbot College	Faculty of Music

**Description of Violation**

Old, unused, CRT monitors stored on floor. Present possible trip/kick hazard.

**Action**

Please remove and/or store properly off the floor on shelves.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3576	Mike	TC22	Talbot College	Faculty of Music

**Description of Violation**

No First Aid kit in area.

**Action**

First Aid rep, Brian Hart, to contact Sintia in OHS @ 80315, to order kit. Brian to create First Aid station with his certificate, poster, etc.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3577	Mike	Loading Dock	Talbot College	Faculty of Music

**Description of Violation**

Ladder leaning against wall in loading dock area, unsecured. Could fall over.

**Action**

Please tether.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 6, 2012</b>	Jan 16, 2012	2012-3578	Mike	104 'Green Roo	Talbot College	Faculty of Music
<b>Description of Violation</b>				<b>Action</b>		
Ancient, moldy, disrepaired, unused frdge in 'Green Room'. Presents health and possible fire/electrical hazard.				Please remove.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 6, 2012</b>	Jan 16, 2012	2012-3573	Mike	C134 (rear area	Talbot College	Physical Plant - Maintenance
<b>Description of Violation</b>				<b>Action</b>		
Tile flooring under mobile shelving is loose, curling and lifting. Presents possible slip/trip to users.				Please repair 'bad' tiles. Was told that this area was due to be renovated but underbudgeting has resulted in significant postponement. Hence repair in the meantime is advised.		
<b>Comments</b>						
WO 193759						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 6, 2012</b>	Jan 16, 2012	2012-3580	Mike	MB113	Music Building	Faculty of Music
<b>Description of Violation</b>				<b>Action</b>		
Hallway outside MB206 has many items stored and left behind (such as old rack, stools, etc). Hallway must be kept clear.				Please remove and keep clear at all times. Told that the 'percussion people' are messy and will not keep area clean. PLEASE ENFORCE.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 6, 2012</b>	Jan 16, 2012	2012-3582	Mike	MB102 Classroom	Music Building	Physical Plant - Maintenance
<b>Description of Violation</b>				<b>Action</b>		
Cover missing off duplex receptacle, near entrance, to classroom.				Please repair		
<b>Comments</b>						
WO 193757						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 6, 2012</b>	Jan 16, 2012	2012-3579	Mike	way outside MB	Music Building	Faculty of Music
<b>Description of Violation</b>				<b>Action</b>		
Hallway outside MB206. Old lockers placed in hallway. Unsecured, could fall over. Very messy area. Many items on floor present trip hazard.				Contact Fire Safety to see if lockers permitted, otherwise remove. If permitted contact Facilities Engineering to secure. Ensure area kept tidy.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 9, 2012</b>	Jan 19, 2012	2012-3584	Mike	le Steps and Wa	Psyc House @ 363 Windermere	Physical Plant - Maintenance

**Description of Violation**

Front, outside steps uneven, sloped, with no handrail. Employee has slipped and questions condition and compliance with code.

**Action**

Please investigate. Consider condition and possible solutions. Determine whether meets standards/code. Please report back to Mike Mosley so he can update tenants.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 20, 2012</b>	Jan 30, 2012	2012-3603	Mike	LwH 2270A	Lawson Hall	History

**Description of Violation**

Old metal shelving laying on floor just inside doorway. Presents a trip hazard.

**Action**

Please remove from doorway and store safely elsewhere.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 20, 2012</b>	Jan 30, 2012	2012-3604	Mike	LwH 2219	Lawson Hall	History

**Description of Violation**

Shelving frame leaning against wall. Could fall over.

**Action**

Please remove, install or secure. Contact Jeff Jones.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 20, 2012</b>	Jan 30, 2012	2012-3605	Mike	LwH 2240	Lawson Hall	History

**Description of Violation**

Shelving frames leaning against wall. Could fall over.

**Action**

Please remove, install or secure. Contact Jeff Jones.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 20, 2012</b>	Jan 30, 2012	2012-3608	Mike	WSS 121	Western Student Services	Western Student Services

**Description of Violation**

Same order as last year however some improvement apparent. Storeroom overcrowded and poor storage. Disorganized, egress route not clear. Trip hazard. No ladder for high storage. Access to shelves difficult.

**Action**

Please continue improvements. Arrange in a proper and safe manner. Appoint a person responsible for monitoring and correcting condition.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Feb 21, 2012</b>	Jan 31, 2012	2012-3612	Mike	UCC 234A	University Community Centre	Western Student Services

**Description of Violation**

First Aid Station in Student Success Centre needs attention.  
 1. No trained First Aid rep poster  
 2. Poster not displayed  
 3. Monthly check not completed.

**Action**

Please review and update. Contact Sintia at 80315 in OHS for supplies and information.

**Comments**

*Total Orders Past Due 16*