

Compliance Orders

Status as at January 19, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3573	Mike	TC134 (rear area)	Talbot College	Physical Plant - Maintenance

Description of Violation

Tile flooring under mobile shelving is loose, curling and lifting. Presents possible slip/trip to users.

Action

Please repair 'bad' tiles. Was told that this area was due to be renovated but underbudgeting has resulted in significant postponement. Hence repair in the meantime is advised.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3574	Mike	Hallway outside TC3	Talbot College	Physical Plant - Maintenance

Description of Violation

UWO Mailbox in hallway outside TC316 has unlocked main door. Swings into hallway and could catch people walking down hall.

Action

Please secure closed. Suggest Mailroom personal (who have necessary keys) relock/secure. If lock is broken Lockshop may need to be involved.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3575	Mike	TC302	Talbot College	Faculty of Music

Description of Violation

Old, unused, CRT monitors stored on floor. Present possible trip/kick hazard.

Action

Please remove and/or store properly off the floor on shelves.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3576	Mike	TC22	Talbot College	Faculty of Music

Description of Violation

No First Aid kit in area.

Action

First Aid rep, Brian Hart, to contact Sintia in OHS @ 80315, to order kit. Brian to create First Aid station with his certificate, poster, etc.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3577	Mike	Loading Dock	Talbot College	Faculty of Music

Description of Violation

Ladder leaning against wall in loading dock area, unsecured. Could fall over.

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3578	Mike	104 'Green Roo	Talbot College	Faculty of Music

Description of Violation

Ancient, moldy, disrepaired, unused frdge in 'Green Room'. Presents health and possible fire/electrical hazard.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3579	Mike	way outside MB	Music Building	Faculty of Music

Description of Violation

Hallway outside MB206. Old lockers placed in hallway. Unsecured, could fall over. Very messy area. Many items on floor present trip hazard.

Action

Contact Fire Safety to see if lockers permitted, otherwise remove. If permitted contact Facilities Engineering to secure. Ensure area kept tidy.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3580	Mike	MB113	Music Building	Faculty of Music

Description of Violation

Hallway outside MB206 has many items stored and left behind (such as old rack, stools, etc). Hallway must be kept clear.

Action

Please remove and keep clear at all times. Told that the 'percussion people' are messy and will not keep area clean. PLEASE ENFORCE.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3581	Mike	3rd floor student lab	Music Building	Faculty of Music

Description of Violation

Microwave sitting high on top of cabinet not secured above bannister. Could fall of, over edge to floor below.

Action

Remove and relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Feb 6, 2012	Jan 16, 2012	2012-3582	Mike	1B102 Classroom	Music Building	Physical Plant - Maintenance

Description of Violation

Cover missing off duplex receptacle, near entrance, to classroom.

Action

Please repair

Comments

Total Orders 10