

# Compliance Orders Past Due as of Jan 19, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 25, 2011</b>	Nov 4, 2011	2011-3523	Mike	Dish Room	Essex Hall Residence	sp. Services - Residence Operati

**Description of Violation**

Shelves in new dishroom need to be secured to wall. Tippy and on wheels. Staff indicate they need not be portable.

**Action**

Please secure securely to wall.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 25, 2011</b>	Nov 4, 2011	2011-3522	Mike	Kitchen area	Essex Hall Residence	sp. Services - Residence Operati

**Description of Violation**

Gas shutoff protrudes into sink area. Staff concerned that could hit head.

**Action**

Please mark with bright tape etc so that it can be easily seen.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 25, 2011</b>	Nov 4, 2011	2011-3514	Mike	UC112F.	University College	Faculty of Arts

**Description of Violation**

Numerous extension cords in use. Extension cords not permitted.

**Action**

Please remove. Replace with power bar.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Dec 13, 2011</b>	Nov 22, 2011	2011-3559	Mike	VAC234	Visual Arts Centre	Visual Arts

**Description of Violation**

Extension cords in use. Extension cords not permitted. Yellow extension cord used to power one area. Black extension cord with duplex receptacle in another.

**Action**

Please remove. Arrange with Facilities Management to have duplex receptacles insalled at necessary locations.

**Comments**

Work order #E11729, submitted November 28, 2011 , by Andrew Silk.

**Total Orders Past Due 4**