

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3894	Mike	DK's Back Hallwa	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Plastic carts are 'parked' in hallway in front of exit (screen door). Prevents egress in case of emergency.

Action

Always store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3895	Mike	DK's Storage	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

In DK's Storage the First Aid Kit has not been checked since 2007 and white inspection tag completed. A copy of certified first aid must also be posted.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3896	Mike	DK's Back Hallwa	Spencer Hall	Physical Plant - Maintenance

Description of Violation

Open electrical box above doorway in back hallway of DK's. Wires are live.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3897	Mike	SEB19	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Buildup of combustibles (styrofoam inserts and cardboard boxes) in front of doorway between labs.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3898	Mike	SEB19A	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Unlabelled chemicals (ie open beaker) in yellow flammable storage cabinet.				Please review all chemicals in cabinet and ensure that they are all properly labelled.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3899	Mike	SEB 15	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Evidence of food and drink being consumed in lab where hazardous materials are present.				Please ensure that food and drink are not consumed in lab. Inform all workers. Monitor.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3900	Mike	SEB 15	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Aluminum step ladder leaning against wall, unsecured. Could fall over.				Please ensure ladder is secured/tethered properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3901	Mike	SEB22A	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
".Garage Door" between shops is broken and slides down to below 5 ft clearance. Dangerously low.				Please repair.		
Comments						
May 14 - I have placed Work order 204683 with physical plant to repair the door.						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3902	Mike	SEB22A	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Extension cord in use to power mixer. Extension cords not permitted.

Action

Please remove extension cord. Arrange to have receptacle installed so that mixer line cord can be plugged in directly.

Comments

WO# 204685 has been put in for a new receptacle for the mixer.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3903	Mike	SEB22A	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Frayed line cord on scale.

Action

Please remove mixer from service until line cord is repaired.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3904	Mike	SEB22A	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Area is a safety shoe required area and all occupants must wear safety shoes at all times.

Action

Please ensure area clearly posted and rules complied with.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3905	Mike	SEB22A	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Hallway cluttered (shelf and clay skid). Hallways must be kept clear and not used for storage.

Action

Please remove all items.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3906	Mike	SEB27 Hallway	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Hallway in vicinity of SEB27 is cluttered. Items abandoned including cylinder cabinet.

Action

Please remove all items immediately. Instruct occupants that hallways should NEVER be used for storage.

Comments

June 7 - All items have been removed with the exception of one gas cylinder storage cabinet. Working on a home for it.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3907	Mike	SEB29	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Service trough has cover plates missing. Large gaps which are a trip hazard.

Action

Please cover.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3908	Mike	way outside SEB	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Hallway outside SEB24 has a skip which protrudes beyond alcove into walking area. Trip hazard.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3909	Mike	SEB37	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3910	Mike	way outside SEB	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Uncertified, wooden flammable storage cabinet in use.				Please remove and dispose of. Alternatively remove all labelling and use for non flammable storage.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3911	Mike	SEB1081C	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Extension cords in use. Not permitted.				Please remove.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3912	Mike	SEB1064	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Same issue of non-compliance as last year. Disorganized storeroom with hazards present. Plywood sheeting stored upright and untethered. Trip hazards. Plexiglass sheet with sharps edges merely sandwiched between two untethered sheets.				Please correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3913	Mike	SEB1071	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Grinder missing safety shield.				Please reinstall shield. Remove grinder from service until guard back in place.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3914	Mike	SEB1076	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Eyewash has not been checked weekly and blue card filled out.			It is the responsibility of lab supervisor to ensure that eyewash is checked weekly and blue card completed.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3915	Mike	SEB1025C	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Orange extension cord in use. Extension cords not permitted.			Please remove.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3916	Mike	SEB1018	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Dropoff from raised floor should be marked so that it is visible to prevent accidental stepping off.			Please mark so that it is visible with striped tape to delineate area.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3917	Mike	SEB1018	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Ladder (orange) leaning unsecured against wall. Could fall over.			Please secure either by tethering or installing proper bracket for hanging.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3918	Mike	SEB1018	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Cover plates missing off holes/access areas in floor.

Action

Please reinstall cover plates.

Comments

June 7 - Mike - I have discussed with Clayton the modifications to be made to the floor covers as you and I discussed. The Shop will modify the covers accordingly. I now need to deliver the covers with appropriate cut-outs marked to Clayton for them to do the work. I will arrange to have them delivered to the Shop tomorrow.
Craig

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3919	Mike	SEB1032	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Disorganized stored on items no longer needed. Left by retired faculty member. Egress and trip hazard.

Action

Please dispose of items. Organize room.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3920	Mike	SEB1041D	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove. Plug appliance/instrument directly into wall receptacle.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3921	Mike	SEB1035	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove. Plug appliance/instrument directly into wall receptacle.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3922	Mike	SEB1068	Spencer Engineering Building	Physical Plant - Maintenance
Description of Violation				Action		
Trip hazard at door- hallway interface in flooring due to transition strip lifting. SEB1068.				Pleae repair.		
Comments						
WO 204598						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3923	Mike	ay outside SEB1	Spencer Engineering Building	Physical Plant - Maintenance
Description of Violation				Action		
In hallway outside SEB1041A the cover plate is missing off duplex receptacle.				Please replace.		
Comments						
WO 204595						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3924	Mike	B17 and SEB10	Spencer Engineering Building	Physical Plant - Caretaking
Description of Violation				Action		
Two fire extinguishers have not been checked monthly and tag filled in. SEB 17 and SEB 1068.				Please check and add to monthly inventory list.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 4, 2012	May 14, 2012	2012-3925	Mike	SEB1	Spencer Engineering Building	Physical Plant - Caretaking
Description of Violation				Action		
Exit sign light is dead. SEB1				Please correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3926	Mike	SEB2016	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Aluminum step ladder unsecured.				Please tether or hang on proper brackets.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3927	Mike	SEB2017	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Chemical management concerns. Some chemicals stored out on bench and some are not clearly labelled.				Please correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3928	Mike	SEB2026	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Combustibles (cardboard boxes) stored on top of flammable storage cabinet.				Please remove and store elsewhere.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3929	Mike	SEB2032	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Cabinet not designed or appropriate as a flammable storage cabinet has been labelled 'Flammable'.				Please remove incorrect label.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3930	Mike	SEB2032	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Unlabelled chemicals in fridge.			Please ensure all chemicals are properly labelled. Review storage in fridge and purge and reorganize as appropriate.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3931	Mike	SEB2033	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Line cord on Biosafety cabinet is cracking and frayed.			Please replace cord.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3932	Mike	SEB2036	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Incorrect chemical storage. Acids and bases stored side by side in a flammable storage cabinet.			Please correct. Remove labels indicating acid and base from cabinet. Dispose of all unneeded chemicals. CALL OHS FOR REINSPECTION WHEN COMPLETE.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3933	Mike	SEB2036	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Items stored in front of electrical panel. Panel must be kept clear for a 1 metre radius.			Please remove items			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3934	Mike	SEB2035	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Chemical management concerns. Storage of chemicals in fumehood and not all chemicals properly labelled.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3935	Mike	SEB2035	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Chemical storage in fridge needs review. Not all chemicals labelled. Many stored on sides, etc.

Action

Please review, purge and organize.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3936	Mike	SEB2035	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Unlabelled carbuoy.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3937	Mike	SEB2046	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Electrical panel blocked by drillpress. A 1 metre radius of clearance must be maintained.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3938	Mike	SEB2046	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Chemical management concerns. Not all chemicals are clearly labelled. Excess of chemicals. Not all stored properly.			Please review. Label. Purge unnecessary chemicals. Store properly.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3939	Mike	SEB2046	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Chemical management concerns in fridge.			Please review ensuring labelling, compatibility, packaging are correct. Purge unnecessary inventory.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3940	Mike	SEB2092	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
Student wearing sandals in laboratory.			Please ensure all workers wear appropriate footwear while working in the lab.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3941	Mike	SEB3015	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation			Action			
First aid kit has not been checked since 2011. Name of first aid rep is not displayed on the kit.			Please check monthly and fill in white tag. Display rep's certificate.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3942	Mike	SEB3015	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Eyewash has not been checked since 2011.				Please check weekly and fill in blue tag.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3943	Mike	ay outside of SEB	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Furniture stored in hallway. Some temporary due to renovations, some not temporary.				Please remove all furniture that will not be used after renovations.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3944	Mike	SEB3054	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Compressed gas cylinder not tethered to cart.				Tether.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3945	Mike	SEB3068	Spencer Engineering Building	Engineering - FACULTY of
Description of Violation				Action		
Untethered gas cylinder.				Please tether.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3946	Mike	SEB3068	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Bookshelf very tippy.

Action

Please secure.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3947	Mike	SEB3068	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Not all chemicals labelled properly with full chemical names. For example on chemical labelled "RGO".

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3948	Mike	SEB3072	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Line cord (HV 208V) needs repair. Wires exposed.

Action

Please repair. Take out of service in meantime.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3949	Mike	SEB3074.	Spencer Engineering Building	Engineering - FACULTY of

Description of Violation

Chemical management concerns. Not all chemicals labelled properly and some chemicals not stored correctly (ie left on floor).

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 6, 2012	May 16, 2012	2012-3950	Mike	B 2038, 3064, 30	Spencer Engineering Building	Physical Plant - Maintenance

Description of Violation

Transition strip between room flooring and hall flooring either in bad repair or missing. Trip hazard. SEB 2038,3064,3072.

Action

Please repair.

Comments

WO 205342

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3951	Mike	TEB336A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Storage room full and disorganized. Excess of cardboard boxes, etc. Egress difficult. Trip hazard.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3952	Mike	TEB338	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Power bars are daisy chained and present a trip hazard.

Action

Please correct. Only one power bar between source and receptacle permitted.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3953	Mike	TEB313A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Biohazard garbage full and overflowing.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3954	Mike	TEB313	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

The portion of the lab allocated for non lab work and the storage of Dr Margaritis old materials is disorganized and unsafe. Old monitors and old cords and cables hanging of shelves could fall. Freezer is plugged in using extension cord and daisy chaining.

Action

Please clean up and make safe.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3955	Mike	TEB313	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Fumehood in lab allocated to Dr. Margaritis (closest to window) is being used for chemical storage and has unlabelled chemicals.

Action

Chemicals should not be stored in fumehood and all chemicals should be labelled. Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3956	Mike	TEB313	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Portion of lab allocated to Dr Bassi shows evidence of food and drink being consumed. Not allowed in areas where hazardous materials are present.

Action

Please remove. Please monitor.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3957	Mike	TEB313	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Power bars daisy chained. Only one power bar permitted between outlet and appliance.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3958	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Unlabelled chemicals. All chemicals must be clearly labelled with full chemical name. Note unlabelled mason jar in lab. Improperly labelled chemicals in fridge.

Action

Please review all chemicals and correct as necessary.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3959	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Flammables stored in fridge that is not intrinsically safe (not designed for flammable storage).

Action

Please purchase new fridge or dispose of flammable chemicals in current fridge. Review all fridge contents.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3960	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Red containers not CLEARLY labelled.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3961	Mike	TEB411	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Not all chemicals in Acid Storage cabinet are clearly labelled.

Action

Please correct. Review all contents and dispose of chemicals that are no longer needed.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3962	Mike	TEB411	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Waste not labelled with full chemical name.

Action

Please ensure all chemicals including waste are clearly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3963	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Fridge at south end of lab is in poor shape. Flammables stored, poor and incomplete labelling, etc.

Action

Review ALL contents and first purge chemicals left behind by departing researchers that are no longer required. Reduce inventory to only necessary items. Ensure all remaining are in good condition and clearly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3964	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Chemicals left out bench - not stored properly.

Action

Please store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3965	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Chemicals in many locations labelled improperly. Short forms not permitted.

Action

Please review ALL CHEMICALS in the lab. Purge as necessary, label as necessary and store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3966	Mike	TEB424A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Bar fridge needs defrosting - AGAIN. Not all contents clearly labelled.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3967	Mike	TEB424A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Poor chemical management. Old chemicals left behind. Acetic acid stored improperly. Leaking chemicals. Flammables stored in places other than flammable cabinet.

Action

Please review all chemical storage and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3969	Mike	TEB406	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Improper and incompatible chemical storage. For example oxidizer stored with acids.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3970	Mike	TEB477A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

First Aid Station needs new first aid trained rep now that former rep has left department.

Action

Please call Shauntel at 80315 to enroll new volunteer in next first aid course. One of the staff members in the main office indicated that she would like to be trained and be the rep. Thank you.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 12, 2012	May 22, 2012	2012-3971	Mike	TEB477	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Extensio cord in use to coffee maker.

Action

Please plug coffee maker directly into outlet. Remove extension cord.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3972	Mike	Machine Shop	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Eyewash has not been checked weekly and blue tag completed.

Action

Please check weekly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3973	Mike	Machine Shop	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Electrical disconnect by loading dock is blocked by scrap and other materials and is not accessible. A 1 metre radius clearance must be maintained.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3974	Mike	Machine Shop	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Ladder labelled 'Walbridge' is leaning against wall, untethered.

Action

Please correct. Tether or hang properly and securely.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3975	Mike	Machine Shop	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Rear outside work area is untidy and littered with materials etc that may be a trip hazard.

Action

Please maintain area in a tidy state. Correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3976	Mike	Machine Shop	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Rear outside aisleway is littered with old disganrder materials. Requests to faculty member/researcher by Machine Shop have gone unanswered. Many trip and fall hazards.

Action

Please clean up an make safe.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3977	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Untethered ladder.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3978	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Eyeswash station has not been checked weekly and blue tag completed.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3979	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Evidence of food and drink in lab area where hazardous materials are present. ie coffee cups.

Action

Please correct. Ensure all workers are informed and monitor compliance.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3980	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Chemical management concerns. Incompatible storage of chemicals, unlabelled chemicals, unused chemicals.

Action

Please review and correct. Dispose of chemicals not longer required, check compatibiliy, check labelling. Complete an inventory for all chemicals in the lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3981	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Latch on flammable storage cabinet is broken.

Action

Please repair.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3982	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Cap missing off floor drain. Trip hazard.

Action

Please reinstall drain cap.

Comments

I have placed WO# 207496 to replace the caps.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3983	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Leg from apparatus is protruding into walkway and may present a trip hazard.

Action

Please make more visible.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3984	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Water bottles are being used as sample bottles. Old label remains and new labelling not present. Dangerous situation.

Action

Remove all old labels and clearly label as to current contents. Strongly recommended using containers other than consumer water bottles.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3985	Mike	TEB24	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Exhaust duct for instrument has collapsed.

Action

Please replace. Take instrument out of service until correction made.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3986	Mike	TEB24A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Power bar screwed to wall used as permanent installation to power instrument. Should be plugged directly into receptacle.

Action

Please correct. Contact Facilities Management to have receptacle installed in appropriate location.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3987	Mike	TEB22	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Red data cable routed across fumehood under countertop and blocks easy access to flammable cabinet underneath.

Action

Please reroute along another pathway, and secure.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3988	Mike	TEB20A	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Not all chemicals are labelled with full chemical names.

Action

Please review all chemicals in the lab and ensure that they are correctly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3989	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Workers were not wearing safety glasses. One worker had trouble finding safety glasses.

Action

Supervisor to inform AND MONITOR compliance by workers in the lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3990	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Eyewash in lab has not been tested weekly and blue tag filled out.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3991	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Not all chemicals in the refrigerator are clearly labelled.

Action

Please review all refrigerator contents. Purge chemicals that are no longer required. Ensure remainder are stored correctly and clearly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3992	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

A number of trip hazards present. Items not longer needed and stored on floor, in aisleways, etc.

Action

Please review storage in lab. Declutter. Purge items no longer needed. Store remainder safely

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 15, 2012	May 25, 2012	2012-3993	Mike	TEB215	Thompson Engineering Building	Engineering - FACULTY of

Description of Violation

Buildup of combustibles in lab. Many empty boxes and cartons.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3994	Mike	BLWT157	Boundary Layer Wind Tunnel	Engineering - FACULTY of

Description of Violation

Items, boxes, etc left in main route through lab. Trip hazard.

Action

Please remove and store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3995	Mike	BLWT157	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Walkway through lab narrowed by desks protruding on both side. Egress difficult.				Please correct. Widen pathway. Relocate desk.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3996	Mike	BLWT155	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Bottles of Olive Oil labelled incorrectly as drinking water.				Please remove incorrect label and label correctly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3997	Mike	BLWT155	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Extension cord (orange) is use and is daisy chained into a power bar. Extension cord not permitted and daisy chaining not permitted.				Remove extension cord.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3998	Mike	BLWT155	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Many items clutter main pathways throughout lab. Possible trip hazard. Impedes egress.				Please correct. Declutter lab.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-3999	Mike	BLWT 146	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Extension cord in use to plug in fridge.				Please remove extension cord and plug fridge directly into electrical outlet.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-4000	Mike	LWT Mezzanine	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Green metal cabinet in hallway impedes flow and materials stored on top.				Please remove cabinet and material.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-4001	Mike	LWT Mezzanine	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Many items clutter floor and walkways. Possible trip hazard. Impedes egress.				Please remove.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-4002	Mike	BLWT 141	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Tall step ladder leaning against wall unsecured.				Please remove or secure/tether properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-4003	Mike	BLWT 141	Boundary Layer Wind Tunnel	Engineering - FACULTY of

Description of Violation

Many materials stored leaning against wall untethered. In danger of falling over an preventing egress and being a trip hazard. Some boxes have already fallen over and block pathway.

Action

Please correct. Tether or store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 21, 2012	May 31, 2012	2012-4004	Mike	BLWT 141	Boundary Layer Wind Tunnel	Engineering - FACULTY of

Description of Violation

Items that are already identified and tagged for removal remain stored in hallway.

Action

Please correct. Don't delay.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 22, 2012	Jun 1, 2012	2012-4005	Mike	WT5 (Downstair	Boundary Layer Wind Tunnel	Engineering - FACULTY of

Description of Violation

Remove E-waste (electronic waste/instrumentation) and surplus items from aiseways to clear pathway.

Action

Please complete.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 22, 2012	Jun 1, 2012	2012-4006	Mike	WT5 (Downstair	Boundary Layer Wind Tunnel	Engineering - FACULTY of

Description of Violation

Remove large number of combustibles and file boxes stacked under wind tunnel. Either discard or send to proper storage (ie archives).

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 22, 2012	Jun 1, 2012	2012-4007	Mike	WT5 (Downstair	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Gerry Dafoe's first aid certification has expired. Kit needs monthly checking and white tag completed.				Please call Shauntel in OHS at 80315 to arrange renewel of Gerry's first aid certification. Please check kit monthly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 22, 2012	Jun 1, 2012	2012-4008	Mike	WT5 (Downstair	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Round material (large diameter metal pipes) lying loose on work floor. Present a possible trip/slip hazard.				Please remove and store properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 22, 2012	Jun 1, 2012	2012-4009	Mike	WT5 (Downstair	Boundary Layer Wind Tunnel	Engineering - FACULTY of
Description of Violation				Action		
Material stored leaning against wall in hallway leading to rear exit and loading dock. Could fall over and prevent egress.				Please remove. If materials must remain then all should be securely tethered.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4010	Mike	CLMP2320	Green Building	Engineering - FACULTY of
Description of Violation				Action		
Some chemicals in the fumehood are not clearly labelled with full chemical names.				Please review and ensure all chemicals are clearly labelled.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4011	Mike	CLMP2320	Green Building	Engineering - FACULTY of

Description of Violation

Bottles of waste are stored on floor beside fumehood.

Action

Please remove from floor and store in proper cabinet(s).

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4012	Mike	CLMP2320	Green Building	Engineering - FACULTY of

Description of Violation

Eyewash station needs to be checked weekly. Needs new blue tag.

Action

Please check. Call Shauntel in OHS @ 80315 if a new tag is needed.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4013	Mike	CLMP 2301	Green Building	Engineering - FACULTY of

Description of Violation

Eyewash has not been checked weekly and blue tag filled out.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4014	Mike	CLMP 2302	Green Building	Engineering - FACULTY of

Description of Violation

Gas cylinder unsecured and free standing.

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4015	Mike	CLMP 2302	Green Building	Engineering - FACULTY of

Description of Violation

Two in use gas cylinders tethered together. Must be tethered individually.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4016	Mike	CLMP 2302	Green Building	Engineering - FACULTY of

Description of Violation

Some chemicals are not clearly labelled with full chemical name.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4017	Mike	CLMP 2302	Green Building	Engineering - FACULTY of

Description of Violation

Evidence of food and drink in lab.

Action

Food and drink are not permitted in a lab where hazardous materials are used. Please inform workers and monitor.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4018	Mike	CLMP 2302	Green Building	Engineering - FACULTY of

Description of Violation

Fumehood cluttered with materials.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4019	Mike	CLMP 2303	Green Building	Engineering - FACULTY of

Description of Violation
 Fumehood cluttered. Storage in fumehood.

Action
 Please correct. Store items properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4020	Mike	CLMP 2315	Green Building	Engineering - FACULTY of

Description of Violation
 In use gas cylinders are not tethered separately as required.

Action
 Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4021	Mike	CLMP 3223	Green Building	Engineering - FACULTY of

Description of Violation
 Eyewash needs to be checked weekly and blue tag filled out.

Action
 Please check weekly and fill out tag.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4022	Mike	CLMP 3223	Green Building	Engineering - FACULTY of

Description of Violation
 Fumehood is cluttered. Improper storage of chemicals, waste, materials, etc.

Action
 Please correct. Store all items in proper location.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4023	Mike	CLMP2316	Green Building	Engineering - FACULTY of

Description of Violation

Unlabelled beakers of chemical stored on floor.

Action

Store properly off floor. Please label clearly with full chemical names.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4024	Mike	CLMP3302	Green Building	Engineering - FACULTY of

Description of Violation

Fridge not labelled as contents/use. This order was written up last year and lab claimed that it had been completed. Fridge still not labelled.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4025	Mike	CLMP3302	Green Building	Engineering - FACULTY of

Description of Violation

Evidence of food and drink in lab (water bottles). Food and drink not permitted in lab.

Action

Lab supervisor to please inform all lab workers and monitor.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4026	Mike	CLMP3302	Green Building	Engineering - FACULTY of

Description of Violation

Acetone bottle out on bench. Stored improperly. Should be in flammable storage cabinet.

Action

Please store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4027	Mike	CLMP3303	Green Building	Engineering - FACULTY of

Description of Violation

Electrical panels blocked by stored materials. A 1 metre radius must be kept clear.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4028	Mike	CLMP Roof	Green Building	Engineering - FACULTY of

Description of Violation

Blue cord for data logger stretched across pathway. Presents trip hazard.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 27, 2012	Jun 6, 2012	2012-4029	Mike	ll with fumehood	Green Building	Physical Plant - Maintenance

Description of Violation

All fumehoods in the Claudette MacKay-Lassonde Pavilion have no sticker from Zettler Associates indicating that the annual face velocity check has been performed.

Action

Please check to see if annual check has been done, If not it should be carried out and also added to next year's schedule.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4030	Mike	RRI 7260	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Cart placed in hallway outside door of lab. Batteries and charger on cart. Storage not permitted in hallways.

Action

Please relocate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4031	Mike	RRI 4274	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Label 'ACID' missing off acid storage cabinet.				Please label clearly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4032	Mike	RRI 4274	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Chemical labelling concerns. Not all chemicals are clearly and properly labelled.				Please review and correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4033	Mike	llway outside 42	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Apparatus stored in the hallway near RRI 4274. Storage not permitted in hallways. Egress issues in case of emergency.				Please relocate.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4034	Mike	RI 4284 and 428	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
IN 4284 and 4286 numerous boxes are stored with present both a combustion hazard and an egress hazard in case of emergency.				Please store boxes outside of the research lab.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4035	Mike	RRI 4288	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Numerous boxes are stored with present both a combustion hazard and an egress hazard in case of emergency.

Action

Please store boxes outside of the research lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4036	Mike	RRI0232	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Some chemicals are not labelled properly (ie flask).

Action

Please review all chemicals and ensure that they are properly labelled with full chemical names.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4037	Mike	RRI0232	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Research fridge is not labelled.

Action

Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4038	Mike	RRI0232	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Old CRT monitors stored on floor. Trip hazard and can impede egress.

Action

Please store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4039	Mike	way outside RRI0	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Old CRT monitors and skid stored on floor of hallway. Trip hazard and can impede egress. Storage not permitted in hallway.				Please remove from hallway and store properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4040	Mike	RRI0234	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Old printer stored on floor at entrance. Trip hazard and can impede egress.				Please remove and store properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4041	Mike	RRI0270	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Lead shield stored upright leaning against wall. Could fall over.				Please tether securely.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4042	Mike	RRI0270	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Bookshelf unsecured to wall. Could fall over.				Please secure.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4043	Mike	RRI0203	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Tygon tubing routed in front of electrical panel. A clearance of 1 metre must be maintained.				Please relocate/reroute/remove as appropriate.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4044	Mike	outside Machin	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Old metal shelving unit has been discarded and stored in hallway. Storage not permitted in hallway.				Please remove.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 3, 2012	Jun 12, 2012	2012-4045	Mike	All Labs	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
In all labs in RRI chemicals are not properly labelled with full chemical names. Short forms are common.				Post an Institute wide list of common short forms in each lab for reference. Cannot include short forms of chemicals or chemical formulae. (not H2O, not EtOH, not DW, etc) Ron Noseworth to compile after consultation and submit to OHS for review.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4046	Mike	RRI 3290	Robarts Research Institute	Robarts Reseach Institute
Description of Violation				Action		
Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.				Please review all containers in the lab (on the bench, in use, in storage) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4047	Mike	RRI3282	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4048	Mike	RRI3278	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4049	Mike	RRI3250C	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4050	Mike	RRI3250D	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4051	Mike	RRI3250	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4052	Mike	RRI3226	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles containing hazardous substances have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4053	Mike	RRI3224	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles, pipette washers, have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4054	Mike	RRI3218	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles, pipette washers, have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4055	Mike	RRI2290A	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles, pipette washers, have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4056	Mike	RRI3226	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles, pipette washers, have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4057	Mike	RRI2222	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Not all containers, wash bottles, carboys, sample bottles, pipette washers, have proper labelling. All containers must have proper, legible labels that clearly communicate the contents.

Action

Please review all containers in the lab (on the bench, in use, in storage, in refrigerators, in freezers) to ensure that they are properly labelled. Ensure WHIMIS labelling regulations are adhered to. Dispose of any chemicals/samples that are no longer required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4058	Mike	RRI3270	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Acid storage cabinet is not labelled as 'ACID' storage.

Action

Please clearly label ACID cabinet. At the same time ensure are other chemical storage cabinets (ie BASE, FLAMMABLE) are also clearly labelled.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4059	Mike	RRI3224	Robarts Research Institute	Robarts Reseach Institute
Description of Violation			Action			
Acid storage cabinet is not labelled as 'ACID' storage.			Please clearly label ACID cabinet. At the same time ensure are other chemical storage cabinets (ie BASE, FLAMMABLE) are also clearly labelled.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4060	Mike	RRI2290A	Robarts Research Institute	Robarts Reseach Institute
Description of Violation			Action			
Acid storage cabinet is not labelled as 'ACID' storage.			Please clearly label ACID cabinet. At the same time ensure are other chemical storage cabinets (ie BASE, FLAMMABLE) are also clearly labelled.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4061	Mike	RRI2276	Robarts Research Institute	Robarts Reseach Institute
Description of Violation			Action			
Acid storage cabinet is not labelled as 'ACID' storage.			Please clearly label ACID cabinet. At the same time ensure are other chemical storage cabinets (ie BASE, FLAMMABLE) are also clearly labelled.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4062	Mike	RRI2222	Robarts Research Institute	Robarts Reseach Institute
Description of Violation			Action			
Acid storage cabinet is not labelled as 'ACID' storage.			Please clearly label ACID cabinet. At the same time ensure are other chemical storage cabinets (ie BASE, FLAMMABLE) are also clearly labelled.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4063	Mike	RRI3250	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Buildup of waste in lab.

Action

Purge hazadous waste every Thursday.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4064	Mike	RRI3250	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Access to eyewash is blocked.

Action

Ensure area around eyewash always kept clear.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4065	Mike	RRI3250	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Building of full sharps containers.

Action

Please remove when full.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4066	Mike	RRI3224	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Materials are stored in fumehood. Fumehoods are not for storage and must be kept clear. Store materials properly.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4067	Mike	RRI3224	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Incompatible chemical storage.

Action

Please correct. Review all chemical storage in lab to ensure compatibilty. Purge items that are no longer required. Review condition of materials stored (ie picric acid)

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4068	Mike	RRI3218	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Containers with brains in flammable liquid must be stored in flammable storage cabinet.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4069	Mike	RRI3218	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Combustibles stored on top of flammable cabinet.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4070	Mike	RRI3218	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Storage in fridge cluttered.

Action

Please review and organize. Ensure proper labelling. Purge as necessary.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4071	Mike	RRI2290A	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Incompatible chemical storage. No designated storage for BASES. Based are stored incorrectly in Flammable cabinet and acid cabinet.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4072	Mike	RRI2290A	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Flammable waste incorrectly stored.

Action

Please stored all flammables, both waste and product, properly in flammable storage cabinet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4073	Mike	RRI2286	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Eyewasy hasn't been tested, and blue tag filled out weekly, as required.

Action

Please correct.q

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4074	Mike	RRI2276	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Incompatible chemical storage. Acids stored incorrectly in flammable storage cabinet.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4075	Mike	RRI2226	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Flammable storage cabinet too full. Chemicals stored on top of chemicals.

Action

Please review contents. Purge materials no longer required to create space so all chemicals can be stored upright on shelves.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4076	Mike	RRI2213	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Power bars 'daisy chained' . Only one power bar permitted between outlet and instrument/appliance.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jul 6, 2012	Jun 15, 2012	2012-4077	Mike	llway outside 324	Robarts Research Institute	Robarts Reseach Institute

Description of Violation

Microwave, kettle, toaster all plugged into same circuit. Overloading circuit and tripping breaker.

Action

Please have separate circuit installed to accommodate load OR separate appliances, and hence the load, between different circuits.

Comments

Total Orders 502