

# Compliance Orders Past Due as of Jun 20, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Mar 27, 2012</b>	Mar 6, 2012	2012-3683	Mike	WSC357 Area	Western Science Centre	Biology

**Description of Violation**

No eyewash station available. This order has be written up previously in Lab Safety inspections.

**Action**

Please work with Facilities Engineering and have eyewash installed soon.

**Comments**

May 3rd - We are still working on how best to deal with this compliance order.  
 June 18th - This Compliance Order should be filled within a month. Completing this Compliance Order will be considerably costly (approx \$15,000) and the Department is working on securing some funding.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Mar 27, 2012</b>	Mar 6, 2012	2012-3671	Mike	BGS0064	Biological & Geological Sciences	Biology

**Description of Violation**

In aquarium room there are a number of power bars daisy chained and extension cords in use. Extension cords are not permitted and only one power bar is permitted between the source receptacle and the device being powered.

**Action**

Please review and correct.

**Comments**

May 3rd - Bryan Neff has only just received the quote from Facilities Management for this work. I foresee that it will be a while until this work is completed....

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Apr 20, 2012</b>	Mar 30, 2012	2012-3787	Mike	MSB452	Medical Sciences Building	Anatomy & Cell Biology

**Description of Violation**

Chemical management problems. Not all chemicals are labelled with full chemical names. It appears many unused chemicals are stored.

**Action**

Please review. Ensure all labels clearly show full chemical names. Consider taking any chemicals that are now longer required to chemical disposal on Thursdays.

**Comments**

April 18th from Michael Wu  
 The chemicals listed in the order belong to a Professor Emeritus. Since the new Chair is due to arrive shortly, we would like to ask you to give us more time to deal with this compliance order. I would bring this to his attention and complete the order as soon as he takes the office. Thanks.

June 1st from Kem Rogers, Acting Chair, Anatomy and Cell Biology  
 This compliance order has not been completed. It will be dealt with in the latter half of June, once that status of a new chair has been updated.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>May 10, 2012</b>	Apr 19, 2012	2012-3874	Mike	way outside Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology

**Description of Violation**

Untethered bookshelves on both sides of hallway. Could topple over and restrict movement.

**Action**

Move bookshelves and tether on one side of hallway.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>May 10, 2012</b>	Apr 19, 2012	2012-3867	Mike	Media Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology

**Description of Violation**

Cover plate missing off receptacle.

**Action**

Please install cover plate.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>May 10, 2012</b>	Apr 19, 2012	2012-3868	Mike	Theatre	Museum of Ontario Archaeology	Museum of Ontario Archaeology

**Description of Violation**

Transition molding between tile and 'wood' flooring has broken off. Presents trip hazard.

**Action**

Please repair.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>May 10, 2012</b>	Apr 19, 2012	2012-3869	Mike	Theatre	Museum of Ontario Archaeology	Museum of Ontario Archaeology

**Description of Violation**

Cover plate missing off light switch beside door.

**Action**

Please install cover plate.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>May 10, 2012</b>	Apr 19, 2012	2012-3872	Mike	Rear Exit	Museum of Ontario Archaeology	Museum of Ontario Archaeology

**Description of Violation**

Untethered 4 x 8 sheet of plywood standing on edge in exit hallway. Could fall over.

**Action**

Hallway must be keep clear. Please remove.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 4, 2012</b>	May 14, 2012	2012-3925	Mike	SEB1	Spencer Engineering Building	Physical Plant - Caretaking

**Description of Violation**

Exit sign light is dead. SEB1

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 4, 2012</b>	May 14, 2012	2012-3918	Mike	SEB1018	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Cover plates missing off holes/access areas in floor.

**Action**

Please reinstall cover plates.

**Comments**

June 7 - Mike - I have discussed with Clayton the modifications to be made to the floor covers as you and I discussed. The Shop will modify the covers accordingly. I now need to deliver the covers with appropriate cut-outs marked to Clayton for them to do the work. I will arrange to have them delivered to the Shop tomorrow.  
Craig

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 4, 2012</b>	May 14, 2012	2012-3906	Mike	SEB27 Hallway	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Hallway in vicinity of SEB27 is cluttered. Items abandoned including cylinder cabinet.

**Action**

Please remove all items immediately. Instruct occupants that hallways should NEVER be used for storage.

**Comments**

June 7 - All items have been removed with the exception of one gas cylinder storage cabinet. Working on a home for it.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 4, 2012</b>	May 14, 2012	2012-3913	Mike	SEB1071	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Grinder missing safety shield.

**Action**

Please reinstall shield. Remove grinder from service until guard back in place.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3944	Mike	SEB3054	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Compressed gas cylinder not tethered to cart.

**Action**

Tether.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3927	Mike	SEB2017	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Chemical management concerns. Some chemicals stored out on bench and some are not clearly labelled.

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3929	Mike	SEB2032	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Cabinet not designed or appropriate as a flammable storage cabinet has been labelled 'Flammable'.

**Action**

Please remove incorrect label.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3930	Mike	SEB2032	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Unlabelled chemicals in fridge.

**Action**

Please ensure all chemicals are properly labelled. Review storage in fridge and purge and reorganize as appropriate.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3934	Mike	SEB2035	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Chemical management concerns. Storage of chemicals in fumehood and not all chemicals properly labelled.

**Action**

Please review and correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 6, 2012</b>	May 16, 2012	2012-3935	Mike	SEB2035	Spencer Engineering Building	Engineering - FACULTY of

**Description of Violation**

Chemical storage in fridge needs review. Not all chemicals labelled. Many stored on sides, etc.

**Action**

Please review, purge and organize.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3963	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Fridge at south end of lab is in poor shape. Flammables stored, poor and incomplete labelling, etc.

**Action**

Review ALL contents and first purge chemicals left behind by departing researchers that are no longer required. Reduce inventory to only necessary items. Ensure all remaining are in good condition and clearly labelled.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3967	Mike	TEB424A	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Poor chemical management. Old chemicals left behind. Acetic acid stored improperly. Leaking chemicals. Flammables stored in places other than flammable cabinet.

**Action**

Please review all chemical storage and correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3966	Mike	TEB424A	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Bar fridge needs defrosting - AGAIN. Not all contents clearly labelled.

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3964	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Chemicals left out bench - not stored properly.

**Action**

Please store properly.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3962	Mike	TEB411	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Waste not labelled with full chemical name.

**Action**

Please ensure all chemicals including waste are clearly labelled.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3960	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Red containers not CLEARLY labelled.

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3959	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Flammables stored in fridge that is not intrinsically safe (not designed for flammable storage).

**Action**

Please purchase new fridge or dispose of flammable chemicals in current fridge. Review all fridge contents.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3958	Mike	TEB413	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Unlabelled chemicals. All chemicals must be clearly labelled with full chemical name. Note unlabelled mason jar in lab. Improperly labelled chemicals in fridge.

**Action**

Please review all chemicals and correct as necessary.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3954	Mike	TEB313	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

The portion of the lab allocated for non lab work and the storage of Dr Margaritis old materials is disorganized and unsafe. Old monitors and old cords and cables hanging of shelves could fall. Freezer is plugged in using extension cord and daisy chaining.

**Action**

Please clean up and make safe.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3965	Mike	TEB420	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Chemicals in many locations labelled improperly. Short forms not permitted.

**Action**

Please review ALL CHEMICALS in the lab. Purge as necessary, label as necessary and store properly.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 15, 2012</b>	May 25, 2012	2012-3993	Mike	TEB215	Thompson Engineering Building	Engineering - FACULTY of

**Description of Violation**

Buildup of combustibles in lab. Many empty boxes and cartons.

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 15, 2012</b>	May 25, 2012	2012-3977	Mike	TEB28	Thompson Engineering Building	Engineering - FACULTY of
<b>Description of Violation</b>				<b>Action</b>		
Untethered ladder.				Please correct.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 15, 2012</b>	May 25, 2012	2012-3990	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of
<b>Description of Violation</b>				<b>Action</b>		
Eyewash in lab has not been tested weekly and blue tag filled out.				Please correct.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 15, 2012</b>	May 25, 2012	2012-3991	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of
<b>Description of Violation</b>				<b>Action</b>		
Not all chemicals in the refrigerator are clearly labelled.				Please review all refrigerator contents. Purge chemicals that are no longer required. Ensure remainder are stored correctly and clearly labelled.		
<b>Comments</b>						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 15, 2012</b>	May 25, 2012	2012-3992	Mike	TEB14	Thompson Engineering Building	Engineering - FACULTY of
<b>Description of Violation</b>				<b>Action</b>		
A number of trip hazards present. Items not longer needed and stored on floor, in aiseways, etc.				Please review storage in lab. Declutter. Purge items no longer needed. Store remainder safely		
<b>Comments</b>						

*Total Orders Past Due 33*