

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 12, 2012	Mar 22, 2012	2012-3765	Anne Marie	124	Chemistry Building	Physical Plant - Maintenance

Description of Violation

Shelves in the cabinet under the fumehood are rusted

Action

Repair

Comments

Chemistry 124 compliance order 2012-3765 is complete. We removed old rusted clips and added stainless steel brackets and cleaned up cabinet

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3766	Anne Marie		Chemistry Building	Physical Plant - Caretaking

Description of Violation

Fire extinguisher not checked monthly MSA 1220A-1 and CHB119

Action

Check monthly

Comments

This compliance order has been completed. Thank you, Jerry.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3767	Anne Marie	079, 074, 094	Chemistry Building	Chemistry

Description of Violation

Acids, bases and synthesized chemicals not not have full chemical names and some old labels are degrading (079)
 1,2,4 DNPA reagent does not have a WHMIS label or the full chemical name (074)
 1-propanol does not have a WHMIS label (094)

Action

Label all chemicals with the full chemical name and attach new labels where required

Comments

Corrective action taken on April 2, 2012 by Robin Hall and Ron Maslen

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3768	Anne Marie	079, 094	Chemistry Building	Chemistry

Description of Violation

Some experimental reagents are flammable but stored in a vented cabinet (079)
 Caffeine in ethanol stored on the lab shelf (094)

Action

Relocate to a flammable solvent storage cabinet

Comments

Corrective action taken by Ron Maslen and Robin Hall on April 2. Additional storage space identified in Rm 053 ChB as a short term solution. A flammable cabinet is in the room and chemicals are to be transferred by April 9, 2012.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3769	Anne Marie	1220A	Materials Science Addition	Chemistry

Description of Violation

Solutions on the solution storage area are not identified with the full chemical name.

Action

Label the shelves to identify the chemicals stored there.

Comments

We have labelled the shelves to identify the chemicals stored on that shelf. Completed today, Thurs. March 29, 2012.
Sue

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3770	Anne Marie	1220	Materials Science Addition	Chemistry

Description of Violation

Non-flammable waste is stored in a container that is labelled flammable waste

Action

Use containers that are not labelled flammable waste

Comments

We have crossed out the flammable label on the waste bottles and in future will buy bottles that are not labelled. This was completed today, Thurs. March 29, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3771	Anne Marie	1220	Materials Science Addition	Chemistry

Description of Violation

Some flammable solvent cabinets are used for acid storage.

Action

Cover the flammable label so that the labelling is not ambiguous

Comments

We have covered the flammable label on the cabinets containing acid storage. There were 3 cabinets total that needed fixing. This was completed on Tues. March 27th. Sue England

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 18, 2012	Mar 28, 2012	2012-3772	Anne Marie	119	Chemistry Building	Chemistry

Description of Violation

Two extension cords are daisy chained together (Clara's desk) and One extension cord and two power bars are daisy chained together (Sandy's desk)

Action

Remove extension cords and use power bars that are plugged directly into the outlet

Comments

Complete - Barakat Misk 5/4/12

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Jun 30, 2012	Mar 28, 2012	2012-3773	Anne Marie	various	Chemistry Building	Chemistry

Description of Violation

There is not an up to date chemical inventory for any of the labs. As the inventory is central to chem-bio stores this is a general order.

Action

Please update. A chemical inventory must be maintained and updated at least annually.

Comments

Process underway with completion expected by 31st July 2012 as per Kim Baines, Chair

Phase 1: April 13, 2012: Completion of test run for the physical count inventory for ChemBioStores and the Electronics Shop and uploading of the information to the main database.

Phase 2: Upon successful completion of Phase 1, Rover would be made available to all labs in the Department of Chemistry for a physical count in each lab. The goal is for all labs to complete their inventory is June 30, 2012.

Phase 3: Upon successful completion of Phase 2, all updated inventories would be uploaded to the main database. A hard copy of the updated inventories would be supplied to all labs in the department by July 31, 2012.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3774	Mike	KB K111	Kresge Building	Epidemiology and Biostatistics

Description of Violation

First Aid Station does not have current first aid rep certificate posted, first aid poster or monthly checking completed.

Action

Please call Sintia at 80315 to enroll in First Aid course and obtain a first aid poster. Please check monthly and indicate on white tag

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3775	Mike	All Anatomy Labs	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

All chemicals in all labs must have full chemical names except where common short forms are used it is acceptable to have a 'legend' clearly posted in each lab to 'translate'.

Action

Please post a list defining all short forms used in each lab. ALL but one of the labs in Anatomy did not have such a list. Consult with Kyle Pollard in Biochemistry who has developed a list which could be used, after review, for Anatomy.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3776	Mike	MSB427	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Uncapped needles/sharps around lab.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3777	Mike	MSB427	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Extension cord in use. Extension cords not permitted.

Action

Please remove. Consider replacing with a power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3778	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Items stacked/stored above centre shelves. Clearance of 18" must be maintained.

Action

Please remove. Same order was written up last year. Ensure items remain cleared away.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3779	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Improper chemical segregation. For example acetic acid stored in acid cabinet.

Action

Please review all chemical storage in the lab. Correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3780	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Fumehood working surface used for storage and is very cluttered.

Action

Please remove items and leave clear.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3781	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Flammable liquids stored on bench. Must be in approved flammable storage cabinet.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3782	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Boxes and combustibles stored tightly around fridge. Fridge needs room to 'breathe'. Risk of overheating.

Action

Please remove boxes from area.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3783	Mike	MSB433	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Not all labelled with full chemical names.

Action

Please ensure all chemicals are labelled correctly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3784	Mike	MSB437	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Incompatible chemical storage. Acids and bases and other chemicals stored together in the acid cabinet.

Action

Please review all chemical storage and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3785	Mike	MSB437	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Not all chemicals labelled with full chemical names.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3786	Mike	MSB437	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Items stored on top of centre shelf. Clearance of 18" must be maintained.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 20, 2012	Mar 30, 2012	2012-3787	Mike	MSB452	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Chemical management problems. Not all chemicals are labelled with full chemical names. It appears many unused chemicals are stored.

Action

Please review. Ensure all labels clearly show full chemical names. Consider taking any chemicals that are now longer required to chemical disposal on Thursdays.

Comments

April 18th from Michael Wu
The chemicals listed in the order belong to a Professor Emeritus. Since the new Chair is due to arrive shortly, we would like to ask you to give us more time to deal with this compliance order. I would bring this to his attention and complete the order as soon as he takes the office. Thanks.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3788	Mike	MSB463	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Unlabelled flasks in acid cabinet.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3789	Mike	MSB463	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Unlabelled chemicals. All chemicals must have full chemical names.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3790	Mike	MSB463	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Storage of chemicals in hood. Chemical should not be stored in hood.

Action

Please remove and store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3791	Mike	MSB469	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Flammables stored out on bench. Both as staining solutions and as stock bottles.

Action

Please store bottles in flammable storage cabinet. Please store/use staining solutions in fumehood rather than out on open bench.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3792	Mike	MSB469	Medical Sciences Building	Anatomy & Cell Biology
Description of Violation			Action			
Fumehood work area cluttered. Fumehood work area must be kept clear of materials and storage.			Please correct.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3793	Mike	MSB469	Medical Sciences Building	Anatomy & Cell Biology
Description of Violation			Action			
Acetic Acid stored incorrectly in acid cabinet.			Please remove and store properly in flammable storage cabinet.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3794	Mike	MSB469	Medical Sciences Building	Anatomy & Cell Biology
Description of Violation			Action			
Storage on top of centre cupboards. A clearance of 18" must be maintained below ceiling.			Please remove items.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3795	Mike	MSB469A	Medical Sciences Building	Anatomy & Cell Biology
Description of Violation			Action			
Garbage left strewn on floor. Some shuffled into corner by door. Untidy and potential slip hazard.			Garbage is to be segregated into proper containers rather than dropped on floor. Please correct.			
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3796	Mike	MSB469A	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Cables routed loosely above door and across floor. Present trip/catch hazard

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3797	Mike	MSB473	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Buildup of waste in lab. Waste to be removed frequently to prevent accumulation.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3798	Mike	MSB473	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Peroxide stored incorrectly on bench. Should be refrigerated.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3799	Mike	MSB473	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Not all chemicals clearly labelled. All chemicals must be labelled with full chemical name.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3800	Mike	MSB475	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation
 Chemicals not properly labelled. Some have short forms. Waste labelled merely as "waste" Full chemical names are required.

Action
 Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3801	Mike	MSB476	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation
 Contact on door still labelled as Lehman.

Action
 Please update.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3802	Mike	MSB476	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation
 New refrigerator not labelled as to owner.

Action
 Please label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3803	Mike	MSB478	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation
 Door contact sign still labelled Lehman.

Action
 Please update info.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3804	Mike	MSB478	Medical Sciences Building	Anatomy & Cell Biology

Description of Violation

Some materials in fridge unlabelled. Must have full chemical names. Also in multiuser fridge must indicate ownership.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3805	Mike	DSB4028	Dental Sciences Building	Anatomy & Cell Biology

Description of Violation

Boxes (combustible) piled on top of flammable cabinet.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3806	Mike	DSB00070	Dental Sciences Building	Anatomy & Cell Biology

Description of Violation

Items stored on top of centre cupboard. A space of 18" must be maintained.

Action

Please remove items from on top of cupboard.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3807	Mike	DSB00076	Dental Sciences Building	Anatomy & Cell Biology

Description of Violation

Acetic acid stored incorrectly in acid cabinet. Must be stored in flammable storage cabinet.

Action

Please correct and review all chemical storage in the lab.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3808	Mike	DSB00076	Dental Sciences Building	Anatomy & Cell Biology

Description of Violation

Chemicals stored in fumehood and not all labelled with full chemical names.

Action

Please remove chemicals and label.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3809	Mike	DSB00076	Dental Sciences Building	Anatomy & Cell Biology

Description of Violation

Graduated cylinder with broken base and exposed sharp edge still in use.

Action

Please discard properly and safely.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3810	Mike	MSB455	Medical Sciences Building	Physical Plant - Maintenance

Description of Violation

Ceiling leak remains unfixed and just draining into garbage can. In lab areas where chemicals are used.

Action

Please repair.

Comments

WO #201226

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3811	Mike	DSB4000	Dental Sciences Building	Physical Plant - Maintenance

Description of Violation

Room is too hot so occupants open windows. When windows open the pressure differential causes ceiling tiles to pop out of Tbar. This is an asbestos area.

Action

Please fasten ceiling tiles.

Comments

WO #201227

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3812	Mike	MSB414	Medical Sciences Building	Medical Biophysics

Description of Violation

Materials piled/stored around fire extinguisher. Make access difficult. Area must be kept clear.

Action

Please clear.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3813	Mike	MSB414	Medical Sciences Building	Medical Biophysics

Description of Violation

Old chemicals stored from a previous owner. Current group has no interest or ownership.

Action

Please clear and send out Thursday as hazardous waste.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3814	Mike	MSB412	Medical Sciences Building	Medical Biophysics

Description of Violation

Waste grease sitting in hood. Unlabelled.

Action

Please label, clear and send out Thursday as hazardous waste.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3815	Mike	MSB411	Medical Sciences Building	Medical Biophysics

Description of Violation

Incompatible chemical storage and chemicals in use in an area where food is concerned.

Action

Please remove and store in an area where food and drink are not consumed and store properly. Alternatively dispose of as hazardous waste if no longer in use.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3816	Mike	496 and 496B an	Medical Sciences Building	Medical Biophysics

Description of Violation

Line cord passes through hole in the wall to power Barnstead units. Two locations.

Action

Please remove. Have duplex GFCI receptacles installed at proper locations.

Comments

April 17 - A work order has been placed for a cost estimate place new outlets in the two locations. The work order number is E12380.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3817	Mike	MSB496C	Medical Sciences Building	Physical Plant - Maintenance

Description of Violation

Facilities Mgmt repaired faulty valve in ceiling and forgot to replace ceiling tiles.

Action

Please replace.

Comments

WO # 201252

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3818	Mike	Outside NSC13	Natural Sciences Centre	Physical Plant - Maintenance

Description of Violation

Transition strip on floor is lifting and presents a trip hazard.

Action

Please repair.

Comments

WO #201228

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3819	Mike	Outside MSB407	Medical Sciences Building	Medical Biophysics

Description of Violation

Photocopier in hallway. May not be permitted.

Action

Contact Frank Faroni in Fire Prevention for a consultation as to whether copier is permitted in hallway. Frank can be contacted at 88266

Comments

April 17th - The photocopier will be moved to MSB Rm 412.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3820	Mike	CSB2705	Clinical Skills	Family Medicine

Description of Violation

Extension cord in use for AV.

Action

Please remove and use power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3821	Mike	Between Appointme	Medical Sciences Building	Hospitality Services - Cash Operatio

Description of Violation

Standup bar/shelf in Tim Horton's area of Between Appointments is not secure and is loosening. Possible danger of falling off.

Action

Please inspect and repair as required.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3822	Mike	MSB113	Medical Sciences Building	Faculty of Medicine and Dentistry

Description of Violation

Students in undergraduate teaching lab are using hazardous materials and are not wearing safety glasses.

Action

Course instructor is responsible for ensuring students wear safety glasses. Please talk to instructor, label door and monitor compliance.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3823	Mike	MSb M127	Medical Sciences Building	Biochemistry

Description of Violation

Not all chemicals are stored properly. Flammables on bench should be stored in flammable storage cabinet.

Action

Please review and correct chemical storage.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 23, 2012	Apr 2, 2012	2012-3824	Mike	Med Student Lo	Medical Sciences Building	Faculty of Medicine and Dentistry

Description of Violation

Extension cord used to power fridge. Extension cords not permitted.

Action

Please plug directly into duplex receptacle.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3825	Mike	MSB150	Medical Sciences Building	Physical Plant - Maintenance

Description of Violation

Orange step ladder not stored properly. Leaned up against wall.

Action

Please remove and store properly.

Comments

WO 201659

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3826	Mike	HSA415	Health Sciences Addition	Pathology

Description of Violation

Storage of chemicals under the fumehood that are no longer needed or no longer have owners.

Action

Please purge as hazardous waste. Ensure remaining chemicals are stored compatibly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3827	Mike	DSB4020	Dental Sciences Building	Pathology

Description of Violation

Two gas cylinders tethered together. In use gas cylinders must be tethered separately.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3828	Mike	DSB4018	Dental Sciences Building	Pathology

Description of Violation

Not all chemicals are labelled with full chemical name.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3829	Mike	All	Dental Sciences Building	Pathology

Description of Violation

Many labs have chemicals labelled with common short forms. There must be a legend posted that identifies acronyms.

Action

Please post list in every lab. See Kyle Pollard in Biochemistry for a list which Kyle has put together. Customize it for Pathology labs if necessary.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3830	Mike	All	Dental Sciences Building	Pathology

Description of Violation

In numerous locations old, unused eyewash stations are still in place.

Action

Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 24, 2012	Apr 3, 2012	2012-3831	Mike	DSB4040	Dental Sciences Building	Pathology

Description of Violation

Departmental storeroom has no step ladder/stool to reach higher shelves.

Action

Please procure a good, sturdy stool/stepladder of adequate size for room and shelving.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 25, 2012	Apr 4, 2012	2012-3832	Mike	MOG227	Mogenson Building	Faculty of Medicine and Dentistry

Description of Violation

Extension cord in use to power printer. Extension cords are not permitted.

Action

Please remove. Consider relocating printer close to duplex receptacle, having a new receptacle installed in necessary location of using a power bar.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 25, 2012	Apr 4, 2012	2012-3833	Mike	MOG225	Mogenson Building	Faculty of Medicine and Dentistry

Description of Violation

First aid station missing poster and copy of first aid rep's certificate.

Action

Please correct. Supplies and posters may be obtained from OHS by calling Sintia at 80315.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3834	Anne Marie	00230D	Materials Science Addition	Chemistry

Description of Violation

There is a gas cylinder that is not in use with the regulator attached

Action

Remove the regulator and put the safety cap on the cylinder

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3835	Anne Marie	Hallway	Materials Science Addition	Chemistry

Description of Violation

First aid kit not inspected

Action

Inspect the first aid kit monthly and record the inspection on the tag

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3836	Anne Marie	6C, 122 and 220	Chemistry Building	Chemistry

Description of Violation

Power bars are daisy chained together

Action

Instal power bars so that they plug directly into an outlet

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3837	Anne Marie	024	Chemistry Building	Chemistry

Description of Violation

Old chemicals are stored in the fridge

Action

Submit as hazardous waste

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3838	Anne Marie	across from 023	Chemistry Building	Chemistry

Description of Violation

First aid kit has not been inspected and does have the certificate of the current rep displayed

Action

Inspect kit monthly and display the certificate of the current rep

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3839	Anne Marie	023	Chemistry Building	Physical Plant - Maintenance

Description of Violation

Loose floor tiles are a slip/trip hazard

Action

Please replace the floor tiles.

Comments

Work order 201521

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3840	Anne Marie	lass blowing shd	Staging Building	Chemistry

Description of Violation

First aid kit needs bandaids

Action

Contact Oleg for a supply of band-aids

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
Apr 26, 2012	Apr 5, 2012	2012-3841	Anne Marie	lass blowing shd	Staging Building	Chemistry

Description of Violation

A large glass pipe is propped up against the wall and could fall or be knocked over.

Action

Relocate to a location where it cannot fall over and secure so that it cannot roll.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3843	Mike	MSB210	Medical Sciences Building	Physiology & Pharmacology

Description of Violation

Untethered gas cylinder. All gas cylinders must be tethered

Action

Please tether.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3845	Mike	B291 and MSB2	Medical Sciences Building	Physiology & Pharmacology

Description of Violation

Freezer rooms (MSB291/293) are multiuser rooms. All chemicals must be labelled with full chemical names and ownship indicated.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3846	Mike	DSB2026	Dental Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
BIOHAZARD label on door of food fridge in student office.				Please remove and label correctly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3847	Mike	DSB2025A	Dental Sciences Building	Physical Plant - Caretaking
Description of Violation				Action		
Safety shower has not had monthly checking by caretaking staff since 2010.				Please check. Add to monthly list.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3848	Mike	DSB2025A	Dental Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Eyewash station has not been checked WEEKLY by occupants and blue tag completed.				Please check and mark weekly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3849	Mike	DSB2025A	Dental Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Extension cord (orange) in use to power small fridge. Extension cords not permitted.				Remove extension cord. Relocate fridge so that it can be plugged directly into duplex receptacle.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3850	Mike	DSB0074	Dental Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Chemicals stored in cupboard under fumehood are not all properly labelled.				Review storage. Label. Dispose of chemicals no longer needed.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3851	Mike	DSB00070	Dental Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Incompatible chemicals stored together in Acid Cabinet. Cabinet is only for acids. Cupboard contains acid, H2O2, flammables, etc together.				Correct. Review all chemical storage in lab and correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3852	Mike	HSA202	Health Sciences Addition	Physiology & Pharmacology
Description of Violation				Action		
Tygon tubing strung across doorway is only held up with tape and is falling. Catch hazard.				Please correct. Consider using hooks above door rather than tape. More secure method required.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3853	Mike	HAS 210	Health Sciences Addition	Physiology & Pharmacology
Description of Violation				Action		
Chemicals in flammable storage cabinet seem to be leaking. Strong odour.				Please review contents of cabinet to ensure full labelling, capatibility and need. Purge chemicals no longer required. Remove non flammables and store properly.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3854	Mike	HAS 210	Health Sciences Addition	Physiology & Pharmacology

Description of Violation

Not all chemicals are labelled properly with full chemical names.

Action

Please review and correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3855	Mike	MSB281	Medical Sciences Building	Physiology & Pharmacology

Description of Violation

Buildup of waste in darkroom. Should be cleared out weekly.

Action

Please dispose of waste every Thursday. Do not permit buildup.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3856	Mike	MSB275	Medical Sciences Building	Physiology & Pharmacology

Description of Violation

Acetic acid stored incorrectly in acid cabinet.

Action

Please remove and store properly and compatibly in flammable storage cabinet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3857	Mike	MSB259	Medical Sciences Building	Physiology & Pharmacology

Description of Violation

Acetic acid stored incorrectly in acid cabinet.

Action

Please remove and store properly and compatibly in flammable storage cabinet.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3858	Mike	MSB 240	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Acetic acid stored incorrectly in acid cabinet.				Please remove and store properly and compatibly in flammable storage cabinet.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3859	Mike	MSB249	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Items stored on top of shelves in centre area up to ceiling. A clearance of 18" must be maintained.				Please remove items.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3860	Mike	MSB225	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Items stored on top of shelves in centre area up to ceiling. A clearance of 18" must be maintained.				Please remove items.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3861	Mike	MSB235A	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Biological Safety cabinet has not had its annual certification in a couple of years.				Please arrange for certification and ensure it is put on the yearly certification list.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3862	Mike	MSB219	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Please review chemicals and purge those no longer required. For example a diethylether dated 1990 should be disposed of.				Please review and correct.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 2, 2012	Apr 11, 2012	2012-3863	Mike	labs in department	Medical Sciences Building	Physiology & Pharmacology
Description of Violation				Action		
Many labs use common short forms on labels. Short forms and acronyms must not be used unless defined using a 'legend' in each lab.				Kyle Pollard has developed a list of common short forms for Biochemistry along with Vicki Lightfoot in Biology. Contact Kyle for his list and modify to each labs needs. Please post list in each lab.		
Comments						
Hi Mike Our Departmental H&S committee will review this at our next meeting, later this month. Bruce May 3 - As a department we will continue to follow the policy that full names must be used until we are able to implement the short form legend.						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3864	Mike	White Reading R	Museum of Ontario Archaeology	Museum of Ontario Archaeology
Description of Violation				Action		
Curled up carpetting stored in corner presents trip hazard when moving through stacks.				Please remove and store elsewhere.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3865	Mike	Storage Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology
Description of Violation				Action		
Boxes piled precariously on top of filing cabinets. Could topple over.				Please remove and store correctly and safely.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3866	Mike	Storage Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Wire signs stored upside down with sharp wire pointing upwards beside entrance to room.

Action

Please remove, store properly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3867	Mike	Media Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Cover plate missing off receptacle.

Action

Please install cover plate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3868	Mike	Theatre	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Transition molding between tile and 'wood' flooring has broken off. Presents trip hazard.

Action

Please repair.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3869	Mike	Theatre	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Cover plate missing off light switch beside door.

Action

Please install cover plate.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3870	Mike	Public Lab	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Materials stored in corner, on floor, present trip hazard for people walking around work table.

Action

Please remove and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3871	Mike	Public Lab	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Octagonal glass case stored precariously on top of shelf. Hangs over edge. Could fall off.

Action

Please remove and store securely.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3872	Mike	Rear Exit	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Untethered 4 x 8 sheet of plywood standing on edge in exit hallway. Could fall over.

Action

Hallway must be keep clear. Please remove.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3873	Mike	Rear Exit	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Extension ladders hanging in hallway. Legs at eye level could present a catch hazard.

Action

Please mark legs so more visible.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3874	Mike	way outside Room	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Untethered bookshelves on both sides of hallway. Could topple over and restrict movement.

Action

Move bookshelves and tether on one side of hallway.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3875	Mike	rchive Mezzanine	Museum of Ontario Archaeology	Museum of Ontario Archaeology

Description of Violation

Gate on upper level of mezzanine needs improvements to improve safety and prevent accidental falling.

Action

Please install lock on gate and install highlight stripes, etc.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3876	Mike	Hallway	AFAR	AFAR

Description of Violation

Items stored in hall the are not cages (which are permitted). Area between TA100 and TA102.

Action

Please remove and keep clear.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3877	Mike	hallway near TA100	AFAR	AFAR

Description of Violation

In the area of the lower hallway adjacent to TA102 (west end) some items are stored in an insecure fasion and also some combustible items are stored.

Action

Please tidy area and remove all combustible items and store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3878	Mike	Stairwell EX2	AFAR	AFAR
Description of Violation				Action		
Stairwell is cluttered (near EX2) with stored items. Includes combustibles.				Remove combustible items and organize. Store items far back so as not to impinge on egress		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3879	Mike	Hallway	AFAR	AFAR
Description of Violation				Action		
Plastic garbage pails not permitted in hallway (outside 122 area).				Please remove or replace with auto closing metal garbage receptacles.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3880	Mike	Room 132 and Hallway	AFAR	AFAR
Description of Violation				Action		
Experimental workstation in hall is too large and uses an extension cord through doorway. Extension cords not permitted and hallway egress must be maintained.				Return original small table and remove extension cord and plug directly into duplex		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3881	Mike	Room 139	AFAR	AFAR
Description of Violation				Action		
Electrical setup for Acoustic Chambers has a number of violations. Extension cords, daisy chained power bars, cords passing thru door seals, etc.				Please set up an inspection program to review electrical integrity every month. Investigate and report on the cost and feasibility of having power inside the chambers to Fire Safety and OHS.		
Comments						

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3882	Mike	Room 225	AFAR	AFAR

Description of Violation

First aid kit has not been checked monthly and tag completed by rep (WBK) since 2010. Certificate of current first aid rep not displayed.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 10, 2012	Apr 19, 2012	2012-3883	Mike	Room 140AB	AFAR	AFAR

Description of Violation

Fire extinguisher not checked.

Action

Please inform caretaking staff to add to list and check.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 16, 2012	Apr 25, 2012	2012-3884	Mike	Office	Insurance Research Lab for Better Hor	IRLBH

Description of Violation

First Aid Rep for facility requires First Aid Certification. It is essential that a trained first aider be available on site when workers present.

Action

Please enroll Andrew in next available course at Western. Please call Sintia in OHS @ 80315 to register.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3885	Mike	First Aid	City Plaza	Continuing Studies at Western

Description of Violation

Copy of current First Aid certificate of First Aid rep should be displayed on kit.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3886	Mike	Dry Storage	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Chrome shelves against wall are not secured to wall in Dry Storage Room. Risk of falling over. Other shelves in room are secured.

Action

Please secure.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3887	Mike	Kitchen	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

First Aid kit has not been checked monthly and white record tag completed.

Action

Please check monthly.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3888	Mike	Dish Room	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Pail/garbage can for broken glass is not labelled. Broken glass receptacles need to have a label to identify purpose.

Action

Please correct. 'Official' labels can be obtained by calling Sintia in OHS @ 80315 or by coming to the office in SSB4190.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3889	Mike	Kitchen	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Eyewash in kitchen needs to be checked WEEKLY and blue record tag completed.

Action

Please correct. Blue tags can be obtained by calling Sintia in OHS @ 80315 or by coming to the office in SSB4190.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3890	Mike	Linen Storage	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Untethered step ladder in Linen Storage. Could fall over. Ladders should be secured when not in use.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3891	Mike	Second Floor Stoa	Spencer Hall	Spencer Conf. Centre OPERATION

Description of Violation

Second Floor Storage continues to be a problem. It is a multi user room. Disorganized storage, items piled (could topple), storage in aiseways (hinders egress/trip hazard), storage across yellow lines. Unwanted items stored taking up needed space (ie. Old projection TVs).

Action

Please correct. Establish a monthly inspection schedule that includes all users.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3892	Mike	PUC Room	Spencer Hall	Spencer Conf. Centre OPERATION

Description of Violation

Yellow ladder untethered in walkway to emergency exit.

Action

Please remove and store properly elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3893	Mike	DK's Dining	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Power and communication cables stretched too tightly between bar and wall. Attempt has been made to cover them but is not effective due to short length.

Action

Please correct. Consider longer lines, new outlets in floor under bar for both data and power, etc.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3894	Mike	DK's Back Hallwa	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

Plastic carts are 'parked' in hallway in front of exit (screen door). Prevents egress in case of emergency.

Action

Always store elsewhere.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3895	Mike	DK's Storage	Spencer Hall	Spencer Conf. Centre DINING

Description of Violation

In DK's Storage the First Aid Kit has not been checked since 2007 and white inspection tag completed. A copy of certified first aid must also be posted.

Action

Please correct.

Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
May 21, 2012	Apr 30, 2012	2012-3896	Mike	DK's Back Hallwa	Spencer Hall	Physical Plant - Maintenance

Description of Violation

Open electrical box above doorway in back hallway of DK's. Wires are live.

Action

Please correct.

Comments

Total Orders 322