

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jul 31, 2012</b>	Jul 10, 2012	2012-4083	Mike	bt Plant - NW cor	ICFAR	Engineering - ICFAR

**Description of Violation**

Long yellow extension cord in use. Also daisy chained into a power bar. Extension cords not permitted. Northwest corner of Pilot Plant.

**Action**

Please remove. Consider having a drop and electrical outlet installed in a convenient/useful location on the wall.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4084	Mike	FEB1048	Faculty of Education Building	Faculty of Education

**Description of Violation**

Dividers, artwork, boards, etc leaning against cage, untethered. Could fall over and present egress hazard.

**Action**

Please remove from hallway OR tether securely.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4085	Mike	FEB1048	Faculty of Education Building	Physical Plant - Caretaking

**Description of Violation**

Exit sign dark.

**Action**

Please replace bulb.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4086	Mike	FEB1054	Faculty of Education Building	Physical Plant - Caretaking

**Description of Violation**

Exit sign dark.

**Action**

Please replace bulb.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4087	Mike	FEB1135	Faculty of Education Building	Physical Plant - Caretaking

**Description of Violation**

Exit sign dark.

**Action**

Please replace bulb.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4088	Mike	FEB1166	Faculty of Education Building	Faculty of Education

**Description of Violation**

Bristol board and construction paper stacked on top of filing cabinet is protruding over edge into pathway from supply/copier room.

**Action**

Please remove and store elsewhere.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4089	Mike	FEB1141	Faculty of Education Building	Faculty of Education

**Description of Violation**

In 'kitchenette area' a power bar is used for appliances. Appliances should be plugged directly in to wall.

**Action**

It was decided that the water cooler should be moved to a different location in the room to free up an outlet so all appliances could be plugged directly in to receptacle.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4090	Mike	FEB1100	Faculty of Education Building	Faculty of Education

**Description of Violation**

Extension cord in use. Line cord draped across floor after exiting cupboard. Presents trip and electrical hazard.

**Action**

Please correct by installing a new duplex receptacle at new location on wall behind lecturn.

**Comments**

THIS DEFICIENCY HAS BEEN WRITTEN UP FOR THE LAST THREE YEARS. THE HAZARD REMAINS.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4091	Mike	FEB1116D	Faculty of Education Building	Faculty of Education

**Description of Violation**

New photocopier has been placed in doorway close to fridge so that passage is narrow and less than the 40" required according to Fire Safety.

**Action**

Please 'reorganize' so that aisleyway is widened.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4092	Mike	FEB2063	Faculty of Education Building	Faculty of Education

**Description of Violation**

Old, abandoned fridge is in poor condition. Moldy inside.

**Action**

Please repair and clean or discard.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4093	Mike	1054 (Music Ro	Faculty of Education Building	Faculty of Education

**Description of Violation**

Electrical problems. Extension cord in use, Daisy chaining. Multitap in use.

**Action**

Please have FE install sufficient outlets in location adjacent to items requiring power.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4094	Mike	050 (Auditorium	Faculty of Education Building	Faculty of Education

**Description of Violation**

Large, aluminum ladder propped upright against wall and is not tethered. Could fall over.

**Action**

Please install tether.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4095	Mike	050 (Auditorium)	Faculty of Education Building	Faculty of Education

**Description of Violation**

Two cans of black, oil based (hence flammable) oil bases paint stored in the open on stage.

**Action**

Please remove and store in an approved, flammable storage cabinet.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4096	Mike	(Auditorium Sea	Faculty of Education Building	Faculty of Education

**Description of Violation**

Two heavy gauge pipes, one 20ft long and one 6ft long stored in audience area of auditorium Trip, fall hazard.

**Action**

Please remove from storage in public area. Store safety elsewhere.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4097	Mike	FEB2038	Faculty of Education Building	Faculty of Education

**Description of Violation**

Long signal cable draped loosely across traffic area.

**Action**

Please reroute and secure. Suggest along baseboard and behind seating.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4098	Mike	FEB1131	Faculty of Education Building	Physical Plant - Maintenance

**Description of Violation**

Dulex receptable has one of the ground holes blocked by a broken off grounding pin. This renders in useless for plugging in an appliance with a grounding plug. This socket is needed.

**Action**

Please repair.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4099	Mike	way outside FEB	Faculty of Education Building	Physical Plant - Maintenance

**Description of Violation**

Ceiling tiles not put back in place after work was done in ceiling area.

**Action**

Please replace.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4100	Mike	airway to FEB20	Faculty of Education Building	Physical Plant - Maintenance

**Description of Violation**

Lighting not working on stairs leading to mezzanine. Bulbs in place. Dark.

**Action**

Please repair.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4101	Mike	1054 (Music Ro	Faculty of Education Building	Physical Plant - Maintenance

**Description of Violation**

Vinyl baseboard peeling off wall by stairs. Presents trip/catch hazard.

**Action**

Please repair.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4102	Mike	B1050 (Auditoriu	Faculty of Education Building	Physical Plant - Maintenance

**Description of Violation**

Vinyl stair edge molding peeling off and lifting on an number of stairs. Held loosely on with duct tape in some locations as a temporary ineffective repair. Trip hazard.

**Action**

Please repair.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4103	Mike	Back room	Books Plus	Books Plus

**Description of Violation**

Large stepladder leaning upright against wall, untethered. Could fall over.

**Action**

Please tether.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4104	Mike	FEB1138	Faculty of Education Building	Fire Safety - CCPS

**Description of Violation**

Fire extinguisher sitting on floor. No wall bracket.

**Action**

Please correct.

**Comments**

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Nov 14, 2012</b>	Oct 24, 2012	2012-4105	Mike	Pharmacy Area	Books Plus	Fire Safety - CCPS

**Description of Violation**

Fire extinguisher sitting on floor. No wall bracket.

**Action**

Please correct.

**Comments**

*Total Orders 530*