

| Due Date  | Issue Date   | Compliance # | OHS Insp.   | Room    | Building                   | Department                |
|---|--------------|--------------|---|---------|----------------------------|---------------------------|
| <b>Jul 6, 2012</b>  | Jun 15, 2012 | 2012-4075    | Mike  | RRI2226 | Robarts Research Institute | Robarts Reseach Institute |
| <b>Description of Violation</b>   |              |              | <b>Action</b>   |         |                            |                           |
| Flammable storage cabinet too full. Chemicals stored on top of chemicals. |              |              | Please review contents. Purge materials no longer required to create space so all chemicals can be stored upright on shelves. |         |                            |                           |
| <b>Comments</b>   |              |              |   |         |                            |                           |
|   |              |              |   |         |                            |                           |

| Due Date   | Issue Date   | Compliance # | OHS Insp.       | Room    | Building                   | Department                |
|--|--------------|--------------|-----------------|---------|----------------------------|---------------------------|
| <b>Jul 6, 2012</b>   | Jun 15, 2012 | 2012-4076    | Mike            | RRI2213 | Robarts Research Institute | Robarts Reseach Institute |
| <b>Description of Violation</b>  |              |              | <b>Action</b>   |         |                            |                           |
| Power bars 'daisy chained' . Only one power bar permitted between outlet and instrument/appliance. |              |              | Please correct. |         |                            |                           |
| <b>Comments</b>  |              |              |                 |         |                            |                           |
|  |              |              |                 |         |                            |                           |

| Due Date  | Issue Date   | Compliance # | OHS Insp.  | Room              | Building                   | Department                |
|---|--------------|--------------|--|-------------------|----------------------------|---------------------------|
| <b>Jul 6, 2012</b>  | Jun 15, 2012 | 2012-4077    | Mike   | llway outside 324 | Robarts Research Institute | Robarts Reseach Institute |
| <b>Description of Violation</b>   |              |              | <b>Action</b>  |                   |                            |                           |
| Microwave, kettle, toaster all plugged into same circuit. Overloading circuit and tripping breaker. |              |              | Please have separate circuit installed to accommodate load OR separate appliances, and hence the load, between different circuits. |                   |                            |                           |
| <b>Comments</b>   |              |              |  |                   |                            |                           |
|   |              |              |  |                   |                            |                           |

| Due Date   | Issue Date   | Compliance # | OHS Insp.   | Room              | Building                          | Department |
|--|--------------|--------------|---|-------------------|-----------------------------------|------------|
| <b>Jul 31, 2012</b>  | Jul 10, 2012 | 2012-4078    | Mike  | est 2/3 of new sh | onmental Science Western Field St | Biology    |
| <b>Description of Violation</b>  |              |              | <b>Action</b>   |                   |                                   |            |
| New storage (2/3 west section used by Biology) needs organization. Trip and fall hazards present. Boxes stacked.   |              |              | Please organize. Told that shelving is planned to be installed by Department of Biology soon. Please install . Consider reducing inventory by purging materials no longer needed. |                   |                                   |            |
| <b>Comments</b>  |              |              |   |                   |                                   |            |
| Sept 11 - by Email from Peter Duenk - It is a work in progress.<br>We put Jane's stuff in the cage she supplied from campus. I am getting quotes for racking / mezzanine to store the items in questions. I am to meet with Hugh and Louise to discuss this further shortly. |              |              |   |                   |                                   |            |

| Due Date            | Issue Date   | Compliance # | OHS Insp. | Room    | Building                               | Department          |
|---------------------|--------------|--------------|-----------|---------|--|---------------------|
| <b>Jul 31, 2012</b> | Jul 10, 2012 | 2012-4079    | Mike      | Trailer | Environmental Science Western Field St | Physics & Astronomy |

**Description of Violation**

Trailer location has been improved significantly since last year. Thank you. Wire has been stacked adjacent to trailer on pathway. Presents trip and cut hazard to persons walking by.

**Action**

Please remove to location off pathway.

**Comments**

| Due Date            | Issue Date   | Compliance # | OHS Insp. | Room             | Building                       | Department                     |
|---------------------|--------------|--------------|-----------|------------------|--------------------------------|--------------------------------|
| <b>Jul 31, 2012</b> | Jul 10, 2012 | 2012-4080    | Mike      | Mudroom/Entrance | (Wonderland Road) Radio Observ | New (Wonderland Road) Radio Ob |

**Description of Violation**

The entrance/mud room to the old farmhouse has a buildup of combustibles (old cardboard boxes).

**Action**

Please remove.

**Comments**

| Due Date            | Issue Date   | Compliance # | OHS Insp. | Room            | Building                       | Department                     |
|---------------------|--------------|--------------|-----------|-----------------|--------------------------------|--------------------------------|
| <b>Jul 31, 2012</b> | Jul 10, 2012 | 2012-4081    | Mike      | Bedroom Storage | (Wonderland Road) Radio Observ | New (Wonderland Road) Radio Ob |

**Description of Violation**

Equipment stored in bedroom in a disorganized manner. Egress difficult. Trip hazards.

**Action**

Please organize and store properly. Consider disposing of any materials no longer required.

**Comments**

| Due Date            | Issue Date   | Compliance # | OHS Insp. | Room            | Building                       | Department                     |
|---------------------|--------------|--------------|-----------|-----------------|--------------------------------|--------------------------------|
| <b>Jul 31, 2012</b> | Jul 10, 2012 | 2012-4082    | Mike      | Bedroom Storage | (Wonderland Road) Radio Observ | New (Wonderland Road) Radio Ob |

**Description of Violation**

Bedroom was sealed by Facilities Management using bracket. Occupants have unsealed room and have used to store materials. Bracket on door frame has sharp edges. Presents cut hazard.

**Action**

IF permission has been obtained to use room please totally remove bracket. Sharp edges. Severe cut hazard. IF permission has not been obtained remove all items and seal room. Bracket not a hazard if room remains sealed as intended.

**Comments**

| Due Date            | Issue Date   | Compliance # | OHS Insp. | Room              | Building | Department          |
|---------------------|--------------|--------------|-----------|-------------------|----------|---------------------|
| <b>Jul 31, 2012</b> | Jul 10, 2012 | 2012-4083    | Mike      | ot Plant - NW cor | ICFAR    | Engineering - ICFAR |

**Description of Violation**

Long yellow extension cord in use. Also daisy chained into a power bar. Extension cords not permitted. Northwest corner of Pilot Plant.

**Action**

Please remove. Consider having a drop and electrical outlet installed in a convenient/useful location on the wall.

**Comments**

*Total Orders 508*