

# Compliance Orders Past Due as of Sep 11, 2012

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Mar 27, 2012</b>	Mar 6, 2012	2012-3683	Mike	WSC357 Area	Western Science Centre	Biology

### Description of Violation

No eyewash station available. This order has be written up previously in Lab Safety inspections.

### Action

Please work with Facilities Engineering and have eyewash installed soon.

### Comments

May 3rd as per Vicky Lighthfoot - Bryan Neff has only just received the quote from Facilities Management for this work. I foresee that it will be a while until this work is completed....  
 July 10th as per Vicky Lightfoot "We are meeting Greg Ackland and Anne Marie on July 18th to finalize plans for this work. The Department is now in a position to fund the work and so the completion is dependent on Facilities Management availability."  
 July 27th as per Vicky Lightfoot "We have a issued a work order to Facilities Management to install an eyewash/safety shower in the MGU "  
 Aug 21st as per Mike McLean "Drawings are required for this work and they are currently being prepared. I expect that the Project Crew will be able to do this in September at the same time as they do the one in B&GS in Des Moser's lab."  
 Sept 10th as per Mike McLean - "The work is with the Project crew to complete. I have copied Randy Regier here to confirm when they will be starting."

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Apr 20, 2012</b>	Mar 30, 2012	2012-3787	Mike	MSB452	Medical Sciences Building	Anatomy & Cell Biology

### Description of Violation

Chemical management problems. Not all chemicals are labelled with full chemical names. It appears many unused chemicals are stored.

### Action

Please review. Ensure all labels clearly show full chemical names. Consider taking any chemicals that are now longer required to chemical disposal on Thursdays.

### Comments

April 18th as per Michael Wu  
 The chemicals listed in the order belong to a Professor Emeritus. Since the new Chair is due to arrive shortly, we would like to ask you to give us more time to deal with this compliance order. I would bring this to his attention and complete the order as soon as he takes the office. Thanks.  
  
 June 1st as per Kem Rogers, Acting Chair, Anatomy and Cell Biology  
 This compliance order has not been completed. It will be dealt with in the latter half of June, once that status of a new chair has been updated.

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jun 12, 2012</b>	May 22, 2012	2012-3966	Mike	TEB424A	Thompson Engineering Building	Engineering - FACULTY of

### Description of Violation

Bar fridge needs defrosting - AGAIN. Not all contents clearly labelled.

### Action

Please correct.

### Comments

Due Date	Issue Date	Compliance #	OHS Insp.	Room	Building	Department
<b>Jul 31, 2012</b>	Jul 10, 2012	2012-4078	Mike	est 2/3 of new sh	onmental Science Western Field St	Biology

### Description of Violation

New storage (2/3 west section used by Biology) needs organzation. Trip and fall hazards present. Boxes stacked.

### Action

Please organize. Told that shelving is planned to be installed by Department of Biology soon. Please install . Consider reducing inventory by purging materials no longer needed.

### Comments

Sept 11 - by Email from Peter Duenk - It is a work in progress.  
 We put Jane's stuff in the cage she supplied from campus. I am getting quotes for racking / mezzanine to store the items in questions. I am to meet with Hugh and Louise to discuss this further shortly.

---

*Total Orders Past Due 4*